

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

a. An overall integrated leakage rate of:

1. $\leq L_a$ (346,000 SCCM), 0.20 percent by weight of the containment air^a per 24 hours at P_a , 50 psig, or
2. $\leq L_t$ (61,600 SCCM), 0.058 percent by weight of the containment air^t per 24 hours at a reduced pressure of P_t , 25 psig.

b. A combined leakage rate of $\leq 0.60 L_a$ (207,600 SCCM), for all penetrations and valves subject to Type B and C tests when pressurized to P_a .

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With either (a) the measured overall integrated containment leakage rate exceeding $0.75 L_a$ (259,500 SCCM) or $0.75 L_t$ (46,200 SCCM), as applicable, or (b) with the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding $0.60 L_a$, restore the leakage rate(s) to within the limit(s) prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR 50 using the methods and provisions of ANSI N45.4 - 1972:

- a. Three Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted at 40 + 10 month intervals during shutdown at either P_a (50 psig) or at P_t (25 psig) during each 10-year service period.
~~The third test of each set shall be conducted during the shutdown for the 10-year plant inservice inspection.~~

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

a. An overall integrated leakage rate of:

1. $\leq L_a$ (346,000 SCCM), 0.20 percent by weight of the containment air^a per 24 hours at P_a , 50 psig, or
2. $\leq L_t$ (44,600 SCCM), 0.042 percent by weight of the containment air^t per 24 hours at a reduced pressure of P_t , 25 psig.

b. A combined leakage rate of $\leq 0.60 L_a$ (207,600 SCCM) for all penetrations and valves subject to Type B and C tests when pressurized to P_a .

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With either (a) the measured overall integrated containment leakage rate exceeding $0.75 L_a$ (259,500 SCCM), or $0.75 L_t$ (33,400 SCCM), as applicable, or (b) with the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding $0.60 L_a$, restore the leakage rate(s) to within the limit(s) prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR 50 using the methods and provisions of ANSI N45.4 - 1972:

- a. Three Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted at 40 \pm 10 month intervals during shutdown at either P_a (50 psig) or at P_t (25 psig) during each 10-year service period. ~~a. The third test of each set shall be conducted during the shutdown for the 10 year plant inservice inspection.~~