

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

October 19, 1984

TELEPHONE
(704) 373-4531

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Ms. E. G. Adensam, Chief
Licensing Branch No. 4

Re: Catawba Nuclear Station
Docket Nos. 50-413 and 50-414

Dear Mr. Denton:

My letter of May 4, 1983 to Mr. D. G. Eisenhower transmitted our response to Generic Letter No. 83-28, "Required Actions Based Upon Generic Implications of Salem ATWS Events". Our response included several commitments specific to Catawba Nuclear Station. Attached is a list of these commitments, referenced to the appropriate section of G. L. 83-28, and the current status of each.

Very truly yours,

Hal B. Tucker
Hal B. Tucker *eur*

ROS/mjf

Attachment

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

NRC Resident Inspector
Catawba Nuclear Station

Mr. Robert Guild, Esq.
Attorney-at-Law
P. O. Box 12097
Charleston, South Carolina 29412

Palmetto Alliance
2135½ Devine Street
Columbia, South Carolina 29205

Mr. Jesse L. Riley
Carolina Environmental
Study Group
824 Henley Place
Charlotte, North Carolina
28207

8410230088 841019
PDR ADOCK 05000413
PDR

A055

Commitments Made In Response to
G. L. 83-28 by Letter from
H. B. Tucker to D. G. Eisenhower 11/4/83

Commitment: Implementation of Reactor Trip Investigation Program.
(Section 1.1)

Status: This program is in place and will be implemented upon initial criticality. Ready for Region II to Review as a TMI Action Item.

Commitment: Issue Catawba Nuclear Station Quality Standards Manual, for Structures, Systems and Components. (Section 2.2.1.1 and 2)

Status: This Manual was issued on May 4, 1984.

Commitment: Provide Description of program to ensure that appropriate design verification and qualification testing is specified during procurement of safety-related components. (Section 2.2.1.5)

Status: A description of this program was submitted by letter from H. B. Tucker to D. G. Eisenhower, February 2, 1984.

Commitment: Provide a description of the Duke Power Company Vendor Interface Program. (Section 2.2.2)

Status: This program was described in detail by letter from H. B. Tucker to D. G. Eisenhower May 7, 1984.

Commitment: Review W Post-Maintenance testing for Reactor Trip System Components and verify its Incorporation into Plant Procedures.
(Section 3.1)

Status: Review to be completed by December 31, 1984.

Commitment: Review of vendor instruction manuals for completeness and consistency, and incorporation of changes into plant procedures.
(Section 3.2)

Status: The Vendor Manual Upgrade Program is in progress.

Commitment: Replace undervoltage trip attachments and verify dimensional tolerance. (Section 4.1)

Status: All work is complete.

Page Two continued

Committment: Incorporate Life Cycle Test Program results into maintenance, replacement and qualification programs.
(Section 4.2)

Status: This program is in progress.

Committment: Modification of shunt trip attachments to provide automatic actuation. (Section 4.3)

Status: Modifications are complete.