

GPU Nuclear Corporation

Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

October 22, 1984

Mr. Walter A Paulson, Acting Chief
Operating Reactors Branch No. 5
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Technical Specification Change Request No. 69, Revision 1

In accordance with 10CFR50.59, 10CFR50.90 and 10CFR50.91, GPU Nuclear Corporation, operator of the Oyster Creek Nuclear Generating Station, Provisional Operating License No. DPR-16, requests changes to Appendix A of that license.

Pursuant to 10CFR50.36(a) GPU Nuclear Corporation submits the Radiological Effluent and Environmental Technical Specifications. As discussed at the May 1984 meeting between members of your staff and Mr. Michael Laggart of our Licensing Department, we request that these Technical Specifications become effective 90 days after approval.

In addition, sections 3.6.A and 4.6.A are being revised as discussed with the NRC staff during the integrated assessment of the Systematic Evaluation Program (SEP) and as described in section 4.36 of NUREG-0822 under Topic XV-16, Radiological Consequences of Failure of Small Lines Carrying Primary Coolant Outside Containment. The staff stated that reactor coolant activity limits at Oyster Creek should be maintained within the limits imposed on new operating reactors, that is, within the limits of the Standard Technical Specifications for General Electric Boiling Water Reactors (NUREG-0123).

Also included, as Attachment I, are responses prepared by Morton and Potter to address the concerns raised by Mr. Wayne Meinke of your staff about proposed deviations from the NRC model specifications.

We are also taking the opportunity by this Technical Specification Change Request to incorporate the new reporting requirements of 10CFR50.73 as outlined in Generic Letter No. 83-43.

This Technical Specification Change Request has been reviewed in accordance with Section 6.5 of the Oyster Creek Technical Specifications.


8410310185 841022
PDR ADOCK 05000219
P PDR

Add: NRC/DL/SSPB
441 Encl
3 3
A009
9/1/92

Pursuant to 10CFR50.91(b)(1), a copy of this Technical Specification Change Request has been sent to the State of New Jersey Department of Environmental Protection.

This Technical Specification Change Request revises our submittal of June 1, 1979. In accordance with 10CFR170.22 a check for \$4000 was enclosed which should be applied to this submittal.

Very truly yours,


P. B. Fiedler
Vice President and Director
Oyster Creek

PBF/dam
0764A

Attachments

cc: Dr. Thomas E. Murley, Administrator
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

NRC Resident Inspector
Oyster Creek Nuclear Generating Station
Forked River, NJ 08731