


PECO ENERGY

PECO Energy Company
Nuclear Group Headquarters
965 Chesterbrook Boulevard
Wayne, PA 19087-5691

October 24, 1995

Docket No. 50-278

License No DPR-56

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: Peach Bottom Atomic Power Station, Unit 3
Issuance of the Core Operating Limits Report
for Reload 10, Cycle 11

Dear Sir:


Enclosed is a copy of the Core Operating Limits Report (COLR) for Peach Bottom Atomic Power Station (PBAPS), Unit 3, Reload 10, Cycle 11 operation.

This report provides the cycle-specific parameter limits for: Maximum Average Planar Linear Heat Generation Rate (MAPLHGR); ARTS MAPLHGR thermal limit multipliers; Single Loop Operation (SLO) MAPLHGR multipliers; Minimum Critical Power Ratio (MCPR); ARTS MCPR thermal limit adjustments and multipliers; Single Loop Operation (SLO) MCPR adjustment; Rod Block Monitor (RBM) Setpoints; and Linear Heat Generation Rate (LHGR) for PBAPS Unit 3, Reload 10, Cycle 11 operation.

These values have been determined using NRC-approved methodology and are established such that all applicable limits of the plant safety analysis are met. This report is being submitted to the NRC in accordance with the PBAPS Unit 3 Technical Specifications Section 6.9.1.e.

If you have any questions concerning this submittal, please contact us.

Sincerely,



G. A. Hunger, Jr., Director
Licensing Section

Enclosure

cc: T. T. Martin, Administrator, Region I, USNRC
W. L. Schmidt, Senior Resident Inspector, USNRC, PBAPS

9510270306 951024
PDR ADOCK 05000278
P PDR

