

Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379-2000

R.J. Adney
Site Vice President
Sequoyah Nuclear Plant

October 23, 1995


U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT (SQN)
UNIT 1 - DOCKET NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 -
LICENSEE EVENT REPORT (LER) 50-327/95012

The enclosed report provides details concerning the identification that surveillance requirements associated with the calibration of analog channels which input to the solid state protection system (SSPS) may not have been performed as required by technical specifications. The procedure implementing the required surveillance was incorrect in that it did not ensure that the alarm and/or trip functions on both trains of the solid state protection system were functionally tested. This condition is being reported in accordance with 10 CFR 50.73(a)(2)(i)(B) as an operation prohibited by the plant's technical specifications.

Sincerely,



R. J. Adney

Enclosure

cc: See page 2

270010
9510300002 951023
PDR ADOCK 05000327
S PDR

TE22
11

U.S. Nuclear Regulatory Commission

Page 2

October 23, 1995

Enclosure

cc (Enclosure):

INPO Records Center
Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, Georgia 30339-5957

Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-2711