



NIAGARA MOHAWK POWER CORPORATION / 300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202 / TELEPHONE (315) 474-1511

September 28, 1984
(NMP2L 0179)

Mr. R. W. Starostecki, Director
U. S. Nuclear Regulatory Commission
Region I
Division of Project and Resident Programs
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point - Unit 2
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is a final report, in accordance with 10CFR30.55(e), for the post weld heat treatment (PWHT) qualification of weld wire used in the fabrication of spent fuel pool heat exchangers. This condition was reported via tel-con to P. Russ of your staff on August 30, 1984.

Very truly yours,

C. V. Mangan
Vice President
Nuclear Engineering and Licensing

CVM/GG/pbd

xc: Director of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

R. A. Gramm, NRC Resident Inspector

8411060518 840928
PDR ADOCK 03000410
S PDR

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT - UNIT 2
DOCKET NO. 50-410

Final Report for the Condition
Concerning PWHT Qualification
of Weld Wire
(55(e)-84-35)

Description of the Condition

At the time of identification of this condition, it was believed that the weld material used in the fabrication of spent fuel pool heat exchangers is required to comply with ASME Code Section III, paragraph ND-2431. Later investigation indicated that the subject heat exchangers have been fabricated in accordance with the ASME Section III, Winter 1975 addendum which did not contain paragraph ND-2431. Paragraph ND-2431 was added in a subsequent edition of the code; therefore, a deficiency does not exist.