

RELAYED TO SOURCE

DOCKETED
October 23, 1984

'84 OCT 25 A11:20

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

OFFICE OF SECRETARY
DOCKETING & RECORDS

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

10/23/84

In the Matter of)	
)	Docket Nos. 50-445 and
TEXAS UTILITIES ELECTRIC)	50-446
COMPANY, <u>et al.</u>)	
)	(Application for Operating
(Comanche Peak Steam Electric)	Licenses)
Station, Units 1 and 2))	

OL

APPLICANTS' RESPONSE TO BOARD
REQUEST FOR INFORMATION
REGARDING CINCHING DOWN U-BOLTS

On October 18, 1984, Judge Bloch telephoned Applicants requesting that they provide the raw data supporting Table 2 ("Observations of Torques in U-Bolts") in the affidavit of Robert C. Iotti and John C. Finneran, Jr. appended to Applicants' Motion for Summary Disposition of CASE's Allegations Regarding Cinching Down of U-Bolts (June 29, 1984). While Judge Bloch did not specify at that time a date by which such information should be supplied, in the October 18, 1984 Memorandum and Order documenting the call (mailed by the NRC on October 19 and received by Applicants on October 22), Judge Bloch directed Applicants to provide such information by October 23, 1984.


Applicants have been able to assemble such information in this short period and append it hereto. However, Applicants request that in the future, should there be some urgent need to provide information on an extremely expedited

8411060557 841023
PDR ADOCK 05000445
G PDR

DS03

schedule, Applicants be given as much notice as possible and some explanation of the basis for the expedited schedule.*

Respectfully submitted,

A handwritten signature in cursive script, appearing to read "William A. Horne", is written over a horizontal line.

Malcolm H. Philips, Jr.

Bishop, Liberman, Cook,
Purcell & Reynolds
1200 Seventeenth Street, N.W.
Washington, D.C. 20036
(202)857-9829

* With regard to instant requests for information, in that Applicants have yet to respond to CASE's answer on the issue of cinching down U-bolts, the urgency of the schedule established is unclear.

Building	Hanger Number	Pipe Size	Torque-Average (ft-lbs)
Reactor Building, Unit 2	HD-507-2	3/4	5
Reactor Building, Unit 2	HD-507-1	3/4	5
Reactor Building, Unit 2	HD-964-2	3/4	8.5
Reactor Building, Unit 2	HD-995-3-102	3/4	4
Safeguard, Unit 2	HD-548-1289	1	5.5
Reactor Building, Unit 2	HD-507-1	1	5
Reactor Building, Unit 2	HD-551-RB-2-71	2	17.5
Reactor Building, Unit 2	HD-551-RB-2-70	2	20
Reactor Building, Unit 2	HD-827-25K2	2	4.5
Reactor Building, Unit 2	HD-827-23K2	2	8
Reactor Building, Unit 2	HD-827-24K2	2	10
Reactor Building, Unit 2	HD-827-28K2	2	5
Reactor Building, Unit 2	HD-827-27K2	2	5
Reactor Building, Unit 2	HD-827-26K2	2	5
Reactor Building, Unit 2	HD-827-29K2	2	5.5
Reactor Building, Unit 2	HD-507-107-R2-2	2	4.5

Building	Hanger Number	Pipe Size	Torque-Average (ft-lbs)
Reactor Building, Unit 2	HD-507-121	2	5.5
Reactor Building, Unit 2	HD-507-108-RB-2	2	7.5
Reactor Building, Unit 2	HD-507-105	2	4.5
Reactor Building, Unit 2	HD-507-109-RB-2	2	5
Safeguard, Unit 2	CS2-202-402-S52R	3	22.5
Reactor Building, Unit 2	CS2-079-410-C42S	3	12.5
Reactor Building, Unit 2	CT2-053-444-C62K	3	12.5
Reactor Building, Unit 2	CT2-053-444-C62K	3	10.0
Safeguard, Unit 2	CS2-318-700-S53R	3	15
Safeguard, Unit 2	CS2-014-401-S52K	3	25
Safeguard, Unit 2	CS2-920-703-S53R	3	20
Reactor Building, Unit 2	DD2-046-404-C56R	3	9
Reactor Building, Unit 2	CC2-207-420-C53R	3	26.5
Reactor Building, Unit 2	CT2-053-402-C62S	3	25
Reactor Building, Unit 2	WP2-001-416-C46R	3	22
Reactor Building, Unit 2	WP2-001-426-C46R	3	30
Reactor Building, Unit 2	DD2-109-433-C43R	3	21.5

Building	Hanger Number	Pipe Size	Torque-Average (ft-lbs)
Reactor Building, Unit 2	WP2-030-422-C46R	3	30
Reactor Building, Unit 2	CS2-079-411-C42K	3	25
Reactor Building, Unit 2	CC2-190-401-C52R	4	25
Reactor Building, Unit 2	MS2-150-450-C52K	4	25
Safeguard, Unit 2	AF2-096-410-S33K	4	35
Safeguard, Unit 2	AF2-103-441-S53K	4	20
Safeguard, Unit 2	AF2-099-419-S33K	4	12.5
Safeguard, Unit 2	AF2-099-419-S33K	4	30
Reactor Building, Unit 2	SI2-306-425-C42K	4	33.5
Safeguard, Unit 2	AF2-102-423-S53S	4	23.5
Safeguard, Unit 2	AF2-102-422-S53K	4	52.5
Safeguard, Unit 2	BR2-018-415-S43R	4	50
Safeguard, Unit 2	BR2-018-417-S43K	4	33
Safeguard, Unit 2	CT2-021-405-S32K	4	44.5
Safeguard, Unit 2	WP2-226-428-S36R	4	35
Safeguard, Unit 2	WP2-226-414-S36R	4	22.5
Safeguard, Unit 2	WP2-226-439-S26R	4	21.5
Safeguard, Unit 2	WP2-226-407-S26R	4	40
Safeguard, Unit 2	SI2-044-431-S22R	4	28
Reactor Building, Unit 2	CC2-193-424-C52R	4	41.5

Building	Hanger Number	Pipe Size	Torque-Average (ft-lbs)
Reactor Building, Unit 2	CC2-193-423-C52R	4	15
Reactor Building, Unit 2	MS2-151-442-C52K	4	13.5
Reactor Building, Unit 2	MS2-151-419-C52R	4	40
Reactor Building, Unit 2	MS2-151-440-C52K	4	27.5
Reactor Building, Unit 2	MS2-151-411-C52R	4	7.5
Reactor Building, Unit 2	SI2-306-425-C42K	4	25.5
Reactor Building, Unit 2	SI2-306-423-C42R	4	60
Reactor Building, Unit 2	SI2-306-401-C42R	4	35
Reactor Building, Unit 2	SI2-306-421-C42R	4	22.5
Reactor Building, Unit 2	VD2-053-403-C46R	4	12.5
Reactor Building, Unit 2	SI2-306-402-C42R	4	27.5
Reactor Building, Unit 2	SI2-306-418-C42R	4	50
Safeguard, Unit 2	CT2-021-404-S32R	4	18.5
Safeguard, Unit 2	CS2-326-410-S56R	6	24.5
Safeguard, Unit 2	CS2-326-401-S56R	6	22
Safeguard, Unit 2	FP-790-9.35	6	42.5
Safeguard, Unit 2	FP-790-9.351	6	25

Building	Hanger Number	Pipe Size	Torque-Average (ft-lbs)
Safeguard, Unit 2	FP-790-9.352	6	25
Safeguard, Unit 2	FP-790-9.353	6	35
Safeguard, Unit 2	FP-790-9.354	6	20
Safeguard, Unit 2	FP-790-9.355	6	20
Safeguard, Unit 2	FP-790-1051	6	20
Safeguard, Unit 2	FP-790-1052	6	35
Safeguard, Unit 2	FP-790-1151	6	22.5
Safeguard, Unit 2	FP-790-1152	6	10
Reactor Building, Unit 2	CC2-246-419-C53R	6	10
Reactor Building, Unit 2	CC2-246-423-C53R	6	10
Reactor Building, Unit 2	SI2-171-401-C42R	6	52.5
Reactor Building, Unit 2	SI2-101-408-C41R	6	75
Safeguard, Unit 2	CS2-063-416-S22R	8	17.3
Safeguard, Unit 2	CS2-063-417-S22K	8	35.5
Safeguard, Unit 2	SI2-037-402-S22R	8	42.5
Safeguard, Unit 2	RH2-056-401-S22R	8	55
Safeguard, Unit 2	RH2-028-403-S32R	8	15
Safeguard, Unit 2	FP-810-125	8	57.5
Safeguard, Unit 2	FP-810-12.55	8	40
Safeguard, Unit 2	FP-810-1351	8	17.5
Safeguard, Unit 2	FP-810-1352	8	22.5

Building	Hanger Number	Pipe Size	Torque-Average (ft-lbs)
Safeguard, Unit 2	FP-810-14S	8	31
Safeguard, Unit 2	FP-810-11S	8	27.5
Safeguard, Unit 2	FP-810-10S	8	8
Safeguard, Unit 2	FP-810-9.5S	8	28
Safeguard, Unit 2	FP-810-9S	8	51.5
Reactor Building, Unit 2	SI2-087-406-C42R	8	40
Reactor Building, Unit 2	SI2-087-409-C42R	8	70
Reactor Building, Unit 2	SI2-087-405-C42R	8	55
Reactor Building, Unit 2	SI2-088-410-C42K	8	46
Turbine Building, Unit 2	HD-2-055-407-T45S	10	10
Turbine Building, Unit 2	HD-2-055-409-T45S	10	21.5
Safeguard, Unit 2	CT2-011-403-S22R	10	21
Safeguard, Unit 2	CT2-012-410-S22K	10	37.5
Safeguard, Unit 2	CT2-083-418-S36R	10	83
Safeguard, Unit 2	CT2-083-417-S36K	10	57
Safeguard, Unit 2	CT2-017-440-S36K	10	31
Reactor Building, Unit 2	SI2-010-403-C46S	10	20
Reactor Building, Unit 2	SI2-015-409-C42R	10	45
Reactor Building, Unit 2	SI2-103-403-C42R	10	37.5

Building	Hanger Number	Pipe Size	Torque-Average (ft-lbs)
Reactor Building, Unit 2	SI 2-103-403-C42R	10	72.5
Safeguard, Unit 2	RH2-058-402-S22R	10	50
Safeguard, Unit 2	RH2-058-402-S22R	10	47.5
Safeguard, Unit 2	RH2-058-401-S22R	10	62.5
Turbine Building, Unit 2	HD-2-318-404-T45S	12	48.5
Turbine Building, Unit 2	EX2-030-404-T45S	12	26
Turbine Building, Unit 2	CO2-042-439-T15D	12	57.5
Turbine Building, Unit 2	CO2-042-438-T15D	12	85
Turbine Building, Unit 2	HD2-318-401-T45S	12	65
Turbine Building, Unit 2	HD2-323-403-T45S	12	41
Safeguard, Unit 2	CC2-159-407-S53R	12	87
Reactor Building, Unit 2	RC2-115-430-C56R	12	40
Turbine Building, Unit 2	EX2-002-401-T45S	14	19.5
Turbine Building, Unit 2	MS2-098-402-T45S	14	95
Turbine Building, Unit 2	TW2-099-402-T35D	14	47.5
Turbine Building, Unit 2	EX2-004-401-T45S	14	57.5
Turbine Building, Unit 2	HD2-044-402-T35S	16	27.5

Building	Hanger Number	Pipe Size	Torque-Average (ft-lbs)
Turbine Building, Unit 2	HD2-045-405-T35S	16	125
Turbine Building, Unit 2	HD2-009-401-T35S	16	75
Turbine Building, Unit 2	VD2-072-402-T35D	16	112.5
Turbine Building, Unit 2	HD2-045-401-T15R	16	69
Turbine Building, Unit 2	HD2-044-406-T15R	16	69
Turbine Building Unit 2	HD2-044-405-T15R	16	72.5
Turbine Building Unit 2	HD2-314-401-T45S	16	72.5
Safeguard, Unit 2	CT2-013-414-S32K	16	126
Safeguard, Unit 2	CT2-013-413-S33R	16	67.5
Safeguard, Unit 2	SI2-076-404-S22K	16	25
Safeguard, Unit 2	CT2-025-405-S22K	16	85
Safeguard, Unit 2	CT2-025-405-S22K	16	95
Safeguard, Unit 2	CC2-031-406-S43K	18	117
Safeguard, Unit 2	CC2-068-407-S33K	18	57.5
Safeguard, Unit 2	CC2-068-402-S33S	18	35
Turbine Building, Unit 2	FW2-001-408-T45R	20	65
Turbine Building, Unit 2	FW2-001-408-T45R	20	108
Turbine Building, Unit 2	VD2-073-402-T35S	24	85

Building	Hanger Number	Pipe Size	Torque	Average (ft-lbs)
Turbine Building, Unit 2	FW2-004-401-T35S	24		35
Turbine Building, Unit 2	FW2-004-402-T35S	24		34
Turbine Building, Unit 2	FW2-009-404-T35S	24		43.5
Turbine Building, Unit 2	HD2-068-401-T15S	24		67.5
Turbine Building, Unit 2	EX2-009-405-T45S	24		40
Turbine Building, Unit 2	CO2-032-403-T45D	24		30
Safeguard, Unit 2	CC2-028-412-S33R	24		62.5
Safeguard, Unit 2	CC2-028-412-S33R	24		65
Turbine Building, Unit 2	MS2-033-001-T44S	26		22
Turbine Building, Unit 2	HD2-016-405-T35R	30		112.5
Turbine Building, Unit 2	CO2-010-402-T45D	30		105
Turbine Building, Unit 2	HD2-016-404-T35R	30		89
Turbine Building, Unit 2	EX2-012-402-T45S	30		55
Turbine Building, Unit 2	VD2-071-402-T35D	40		61
Turbine Building,	VD2-070-403-T35D	40		82.5

'84 OCT 25 A11:20

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of)	
TEXAS UTILITIES ELECTRIC)	Docket Nos. 50-445 and
COMPANY, <u>et al.</u>)	50-446
(Comanche Peak Steam Electric)	(Application for
Station, Units 1 and 2))	Operating Licenses)

CERTIFICATE OF SERVICE

I hereby certify that copies of "Applicants' Response to Board Request for Information Regarding Cinching Down U-Bolts", in the above-captioned matter was served upon the following persons by express delivery (*), or deposit in the United States mail, first class, postage prepaid, this 23rd day of October, 1984, or by hand delivery (**) on the 24th day of October, 1984.

**Peter B. Bloch, Esq.
Chairman, Atomic Safety and
Licensing Board
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Chairman, Atomic Safety and
Licensing Appeal Panel
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

* Dr. Walter H. Jordan
881 West Outer Drive
Oak Ridge, Tennessee 37830

Mr. William L. Clements
Docketing & Service Branch
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

* Dr. Kenneth A. McCollom
Dean, Division of Engineering
Architecture and Technology
Oklahoma State University
Stillwater, Oklahoma 74074

**Stuart A. Treby, Esq.
Office of the Executive
Legal Director
U.S. Nuclear Regulatory
Commission
7735 Old Georgetown Road
Room 10117
Bethesda, Maryland 20814

Chairman, Atomic Safety
and Licensing Board Panel
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555


Mr. John Collins
Regional Administrator,
Region IV
U.S. Nuclear Regulatory
Commission
611 Ryan Plaza Drive
Suite 1000
Arlington, Texas 76011

Renea Hicks, Esq.
Assistant Attorney General
Environmental Protection
Division
P.O. Box 12548
Capitol Station
Austin, Texas 78711

**Ellen Ginsberg, Esquire
Atomic Safety and Licensing
Board Panel
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

* Mrs. Juanita Ellis
President, CASE
1426 South Polk Street
Dallas, Texas 75224

Lanny A. Sinkin
114 W. 7th Street
Suite 220
Austin, Texas 78701


William A. Horin

cc: John W. Beck
Robert Wooldridge, Esq.