



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

July 31, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: LaSalle County Station Unit 2
Emergency Amendment to Technical
Specification for Facility Operating
License NPF-18 Reactor Scram on Low
Control Rod Drive Pump Discharge
Pressure Modification
NRC Docket No. 50-374

- References (a): NPF-18 License Condition 2.C(7) Low
Pressure in Pump Discharge of the
Control Rod Drive.
- (b): FSAR Section 4.6.2 pages 4.6-9, 26, 31.
- (c): FSAR Section 7.2 pages 7.2-8, 10, 65,
65a, 65b, 65c, 92, 93, Figure 7.2-5.
- (d): SSER #2 4.6.2, Control Rod System.
- (e): SSER #7 7.2, Control Rod Drive Low Charging
Pressure Scram.
- (f): J. G. Marshall to H. R. Denton dated
May 24, 1984.

Dear Mr. Denton:

Commonwealth Edison requests an emergency amendment to Facility Operating License NPF-18. Reference (f) submitted the original request, in accordance with License Condition 2.C.(7) and was approved as Amendment No. 3 effective July 24, 1984. Commonwealth Edison was not aware of that approval until verbally notified on July 30. The Station has initiated the modification work to incorporate this reactor scram; on July 30 testing of the modification identified spurious scrams which at this point we cannot identify their origin. The Unit is currently shut-down and we wish to restart the Unit tonight. Therefore, we intend to jumper out this low pressure scram logic. Accordingly, Commonwealth

8408060144 840731
PDR ADOCK 05000374
P PDR

Rec'd w/CHCK \$150.00

Acc'd
1/0

July 31, 1984

Edison requests relaxation from the requirements of Amendment No. 3 to meet the requirements of License Condition 2.C(7) i.e., to relax the effective date of the amendment to prior to completion of the startup test program. Plant startup testing is expected to be completed sometime in October, 1984. References (d) and (e) provided interim justification to at least the completion of the startup test program and we feel they both are still applicable. We have reviewed this amendment request and find the original significant hazards consideration, as provided in reference (f), is still applicable.

In accordance with 10CFR170, a fee remittance of \$150.00 is enclosed.

Please direct any questions you may have concerning this matter to this office.

Three (3) signed originals and thirty-seven (37) copies of this transmittal are provided for your use.

Very truly yours,



B. Rybak
Nuclear Licensing Administrator

lm

cc: Region III Inspector - LaSalle
A. Bournia - NRR
G. Wright - Ill.

SUBSCRIBED and SWORN to
before me this 31st day
of July, 1984



Notary Public