

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

Log # TXX-4240
File # 10035

July 27, 1984

Mr. B. J. Youngblood, Chief
Director of Nuclear Reactor Regulation
Licensing Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
GENERIC LETTER 83-10c
PLAN FOR RESOLUTION OF TMI ACTION
ITEM II.K.3.5 "AUTOMATIC TRIP OF
REACTOR COOLANT PUMPS"

Dear Mr. Youngblood:

The WOG Manual RCP Trip Justification Report has been reviewed and CPSES is bounded by the results. Therefore, CPSES is in compliance with Section I.2 of Generic Letter 83-10c.

Also, in reference to Section I.3.a of the generic letter, CPSES has evaluated the effects of instrument accuracy upon the RCP trip setpoints. These effects will be included in the calculation of the RCP trip setpoints and will be incorporated in the Emergency Operating Procedures.

This concludes the CPSES response to NRC Generic Letter 83-10c.

Sincerely,

H. C. Schmidt
H. C. Schmidt

RWH:grr

cc - Mr. John J. Stefano

8408060165 840727
PDR ADDCK 05000445
A PDR

*13001
1/0*