

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED: _____
EXPIRES: _____

FACILITY NAME (1): LaSalle County Station Unit 1	DOCKET NUMBER (2): 0 5 0 0 0 3 7 3 8 4 - 0 4 3 - 0 0 0 2	LER NUMBER (6):			PAGE (2): OF 0 2
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	

TEXT (If more space is required, use additional NRC Form 305A's) (17)

I. EVENT DESCRIPTION

On June 27, 1984, at 0510 hours with Unit 1 at 71% power, while the "A" Reactor Water Cleanup Filter/Demineralizer was being de-isolated, the Reactor Water Cleanup (CE) system isolated (JM) on high differential flow. No high temperature alarms or other indications of system leakage occurred.

II. CAUSE

The cause of this Reactor Water Cleanup system isolation is unknown. It is suspected that the demineralizer partially drains prior to being placed on line. Then when the bed is placed on line it fills, which causes an erroneous differential flow while filling.

III. PROBABLE CONSEQUENCES OF THE OCCURRENCE

The event was not significant, because the Reactor Water Cleanup system isolated as designed. An inspection was performed and no leaks were found. The system was then returned to normal.

IV. CORRECTIVE ACTIONS

An Action Item Record (1-84-67113) has been issued to further investigate this type of Reactor Water Cleanup isolation problem.

V. PREVIOUS EVENTS

A similar occurrence was described in LER 50-373/84-32.

VI. NAME AND TELEPHONE NUMBER OF PREPARER

John Arand, (815)357-6761, extension 463.



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

July 25, 1984

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #84-043-00, Docket #050-373 is being submitted to your office in accordance with 10 CFR 50.73.

G. J. Diederich
Superintendent
LaSalle County Station

GJD/MLD/kg

Enclosure

xc: NRC, Regional Director
INPO-Records Center
File/NRC

IE22
1/1