



PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Donald C. Shelton
SENIOR VICE PRESIDENT
NUCLEAR

October 25, 1995
PY-CEI/NRR-1993L

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
Ohio Environmental Protection Agency Approval for Essential Maintenance
Discharge Change

Gentlemen:

Enclosed is a copy of the Ohio Environmental Protection Agency's (OEPA) approval for a revision to an essential maintenance discharge change requested for the Perry Nuclear Power Plant (PNPP). This information is provided in accordance with the PNPP Operating License, NPF-58, Appendix B, Environmental Protection Plan, Section 3.2.

If you have questions or require additional information please contact Louise Barton at (216) 280-5512.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'D. Shelton', followed by a horizontal line.

Enclosure

LKB:vah

cc: NRR Project Manager
Resident Inspector Office
NRC Region III

9511010283 951025
PDR ADOCK 05000440
S PDR

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

JE23



State of Ohio Environmental Protection Agency

Northeast District Office

2110 E. Aurora Road
Twinsburg, Ohio 44087-1969
(216) 425-9171
FAX (216) 487-0769

George V. Voinovich
Governor

October 11, 1995

Re: 3IB00016
Perry Nuclear Power Plant
Essential Maintenance Discharge Change
Lake County
Industrial

Cleveland Electric Illuminating Co.
Perry Nuclear Power Plant
P.O. Box 97
Perry, Ohio 44081

Attn.: Donald C. Shelton, Sr. VP, Nuclear

Dear Mr. Shelton:

This writer has no objection to the changes in pumping activities that are described in your correspondence letter dated September 1, 1995. The total volume of water being pumped is unchanged and does not exceed the design capacity of each storm drain system. Monitoring of the discharge is required as stated in this writer's letter to you dated July 31, 1995.


Should you have any questions, please contact the undersigned at (216)963-1183.

Sincerely,

Marie F. Underwood
District Engineer
Division of Surface Water

MFU:crh





PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Donald C. Shelton
SENIOR VICE PRESIDENT
NUCLEAR

September 1, 1995
PY-CEI/OEPA-0228L

Attention: Marie Underwood
Ohio Environmental Protection Agency
Northeast District Office
2110 East Aurora Road
Twinsburg, Ohio 44087

Perry Nuclear Power Plant
NPDES Permit No. 3IB0016*DD
Essential Maintenance Discharge Change

Ladies and Gentlemen:

Following is the information we discussed during our phone conversation on August 9, 1995 about revisions to the flow rates to the plant storm drain systems during essential maintenance to be performed on the Perry Nuclear Power Plant service water and circulating water systems.

The changes pertain only to the pumping activities starting on or near 1/25/96. Instead of 10,000 gpd over a ten day period being pumped to the storm drain system on the east side of the plant site, the maximum flow will be 50,000 gpd for a minimum of two days.

The maximum flow to the storm drain system on the west side of the plant site will be 130,000 gpd for a minimum of two days instead of 26,000 gpd for ten days.

Note that the total volumes to be pumped have not changed.

The capacity of each storm drain system is 56,160,000 gpd; the proposed flows will not exceed this value.

If you have questions or require additional information, please contact Louise Barton at (216) 280-5512.

Very truly yours,

[Handwritten signature] for D. C. Shelton

LKB:sc

cc: NRC Document Control Desk (Docket Number: 50-440)
NRC Project Manager
NRC Resident Inspectors Office
NRC Region III
Operating Companies
Cleveland Electric Illuminating
Toledo Edison