



GULF STATES UTILITIES COMPANY

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704

AREA CODE 713 838-6631

July 27, 1984


RBG-18318

File Nos. G9.5, G9.25.1.1

Mr. John T. Collins, Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV, Office of Inspection and Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Dear Mr. Collins:

River Bend Station Unit 1
Docket No. 50-458
Interim Report/DR-140



The Field Quality Control (FQC) Inspection results show that for standby diesel generator IEGS*EGIA, the fuel oil piping and header assembly were installed in accordance with TDI Drawing No. 03-458-08. The FQC inspection of standby diesel generator IEGS*EGIB will be performed in the near future in conjunction with the Preliminary Test Organization testing program. An interim or final status report concerning the engine-mounted fuel oil line in the standby diesel generators supplied by Transamerica Delaval Incorporated (TDI) will be provided by October 11, 1984.

Sincerely,

J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

uplet PJD
JEB/PJD/lp

cc: Director of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

NRC Resident Inspector-Site

8408080236 840727
PDR ADOCK 05000458
S PDR

IE-27

1/0