

REACTOR COOLANT SYSTEM

REACTOR COOLANT SYSTEM LEAKAGE

OPERATIONAL LEAKAGE

SURVEILLANCE REQUIREMENTS

4.4.6.2.2 Each Reactor Coolant System Pressure Isolation Valve specified in Table 3.4-1 shall be demonstrated OPERABLE by verifying leakage to be within its limit:

- a. At least once per 18 months,
- b. Prior to entering MODE 2 whenever the plant has been in COLD SHUTDOWN for 7 days or more and if leakage testing has not been performed in the previous 9 months,
- c. Prior to returning the valve to service following maintenance, repair, or replacement work on the valve, and
- d. Within 24 hours following valve actuation due to automatic or manual action or flow through the valve.*
- e. As outlined in the ASME Code, Section XI, paragraph IWV-3427(b).

The provisions of Specification 4.0.4 are not applicable for entry into MODE 3 or 4.

* Not applicable to RHR pumps 8A and 8B suction isolation valves and their bypass check valves.

SEABROOK - UNIT 1

3/4 4-23

Amendment No. 30-