

Attachment 1 to
ULNRC- 2533

REVISED
PROPOSED TECHNICAL SPECIFICATION CHANGES
Specification 3/4.6.1.2

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of less than or equal to L_a , 0.20% by weight of the containment air per 24 hours at P_a , 48.1 psig.
- b. A combined leakage rate of less than $0.60 L_a$, for all penetrations and valves subject to Type B and C tests, when pressurized to P_a , 48.1 psig.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

Insert A 7

~~With either the measured overall integrated containment leakage rate exceeding $0.75 L_a$ or the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding $0.60 L_a$, restore the overall integrated leakage rate to less than $0.75 L_a$ and the combined leakage rate for all penetrations subject to Type B and C tests to less than $0.60 L_a$ prior to increasing the Reactor Coolant System temperature above 200°F.~~

SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR Part 50 using the methods and provisions of ANSI N45.4-1972:

AREA OF CHANGE

Leave this surveillance as is.

- a. Three Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted at 40 ± 10 month intervals during shutdown at a pressure not less than P_a , 48.1 psig, during each 10-year service period.

~~The third test of each set shall be conducted during the shutdown for the 10-year plant inservice inspection;~~

- b. If any periodic Type A test fails to meet $0.75 L_a$, the test schedule

for subsequent Type A tests shall be reviewed and approved by the Commission. If two consecutive Type A tests fail to meet $0.75 L_a$,

a Type A test shall be performed at least every 18 months until two consecutive Type A tests meet $0.75 L_a$, at which time the above test schedule may be resumed. The as left overall integrated containment leakage rate shall be less than $0.75 L_a$;

INSERT A

ACTION:

- a. With the overall integrated containment leakage rate exceeding $1.0 L_a$, perform the ACTION of Specification 3.6.1.1.
- b. With the as left overall integrated containment leakage rate exceeding $0.75 L_a$, restore the overall integrated leakage rate to less than $0.75 L_a$ prior to increasing the Reactor Coolant System temperature above 200°F .
- c. With the combined leakage rate for all penetrations and valves subject to Type B and C tests exceeding $0.60 L_a$:
 - 1) Restore the combined leakage rate to less than $0.60 L_a$ within 4 hours, or
 - 2) Isolate each failed penetration within 4 hours by use of at least one closed manual valve or blind flange, or a deactivated automatic valve secured in the closed position, or
 - 3) Be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

AREA OF CHANGE—INSERT B—

- ~~a. Three Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted during each 10-year service period at approximately equal intervals, with the third test of each set conducted as close as practical to the end of the 10-year period, during shutdown at a pressure not less than P_a , 48.1 psig.~~