



GPU Nuclear Corporation
Post Office box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4600
Writer's Direct Dial Number:

C321-92-2015

January 15, 1992

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Monthly Operating Report

In accordance with the Oyster Creek Nuclear Generating Station Operating License No. DPR-16, Appendix A, Section 6.9.1.C, enclosed are two (2) copies of the Monthly Operating Data (gray book information) for the Oyster Creek Nuclear Generating Station.


The report for December, 1991, includes revised pages of the Operating Status since startup from our 13R outage on June 25, 1991. These revisions were due to:

- 1) Derating Maximum Dependable Capacity Gross from 642 to 632 MWe, and Net from 620 to 610 MWe due to the replacement of turbine blading with a pressure plate.
- 2) Gross Thermal Energy was revised to account for the change in core thermal power after a feedwater flow test revealed inconsistencies between test measured and indicated feedwater flow.
- 3) Finally, minor corrections were made to the Forced Outage Hours for August, September, October, and November due to mathematical error.

In all cases revision bars have been placed next to the revised numbers.

If you should have any questions, please contact Brenda DeMerchant, Oyster Creek Licensing Engineer at (609) 971-4642.

Sincerely,


J.D. Barton
Vice President and Director
Oyster Creek

JJB/BDEM: jc
Attachment
cc: Administrator, Region 1
Senior NRC Resident Inspector
Oyster Creek NRC Project Manager