



Nebraska Public Power District

GENERAL OFFICE
P.O. BOX 499, COLUMBUS, NEBRASKA 68601-0499
TELEPHONE (402) 564-8561

NLS8400188

July 9, 1984

Mr. John T. Collins
Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive
Suite 1000
Arlington, Texas 76011

Dear Mr. Collins:

Subject: Semiannual Operating Report - Radioactive Effluents - Errata
Cooper Nuclear Station
July 1, 1983, through December 31, 1983
NRC Docket 50-298, DPR-46

Recently an error was found in the second semiannual operating report for Cooper Nuclear Station. The error consisted of an error in the input to GASPAR that resulted in the doses to maximum individual from ground-level and elevated releases being incorrectly summed.

Attached are corrected versions of Tables 5, 6, 9, and 11 of Appendix C of the July 1, 1983 - December 31, 1983, semiannual report.

Sincerely,

Jay M Pilant
Technical Staff Manager
Nuclear Power Group

JMP/dgl:dg
Enclosures

cc: Document Control Desk w/Enclosures
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

8408100014 840709
PDR ADOCK 05000298
R PDR

1824
11