

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Bart D. Withers
President and
Chief Executive Officer

February 17, 1992

WM 92-0022

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Reference: Letter NO 92-001 dated January 6, 1992 from
J. A. Bailey, WCNO, to the NRC
Subject: Docket No. 50-482: Reactor Containment Building
Integrated Leak Rate Test


Gentlemen:

The purpose of this letter is to transmit the results of the second periodic Reactor Containment Building Integrated Leak Rate Test performed during the fifth refueling outage. Attachment 1 provides the Reactor Containment Building Integrated Leak Rate Test report. Attachment 2 provides a summary report of Type "A", "B", and "C" leakage tests which failed to meet the acceptance criteria of 10 CFR 50 Appendix J, Sections III.A.5(b), III.B.3 and III.C.3, respectively. These reports are being provided in accordance with 10 CFR, Appendix J.

The Reference transmitted Licensee Event Report 91-020-01 which discussed the failure of Essential Service Water system valves EF HV-32 and EF HV-34. The failure of the valves caused the Type "A" test "as found" leakage rate to exceed L. In the "as left" condition the Integrated Leak Rate Test was considered successful. The Reference discussed the actions taken as a result of the valve failures and requested NRC review and approval of the Type "A" test schedule.

If you have any questions concerning this matter, please contact me or Mr. S. G. Wideman of my staff.

Very truly yours,



Bart D. Withers
President and
Chief Executive Officer

210047

BDW/aem

Attachments

cc: A. T. Howell (NRC), w/a
R. D. Martin (NRC), w/a
G. A. Pick (NRC), w/a
W. D. Reckley (NRC), w/a

9202240323 920217
PDR ADOCK 05000482
P PDR

Box 411 - Burlington, KS 66839 - Phone: (316) 364-8831

An Equal Opportunity Employer M.F.HC/VET

AO17