

# NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY  
WESTERN MASSACHUSETTS ELECTRIC COMPANY  
HOLYOKE WATER POWER COMPANY  
NORTHEAST UTILITIES SERVICE COMPANY  
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270  
HARTFORD, CONNECTICUT 06141-0270  
(203) 665-5000

August 3, 1984

Docket No. 50-336  
B11268

Director of Nuclear Reactor Regulation  
Attn: Mr. James R. Miller, Chief  
Operating Reactors Branch #3  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Reference: K. L. Heitner letter to W. G. Council, dated May 16, 1984.

Gentlemen:


Millstone Nuclear Power Station, Unit No. 2  
Safety Evaluation of Amendment No. 95 to DPR-65

Amendment No. 95 to Facility Operating License No. DPR-65 was forwarded to Northeast Nuclear Energy Company by the referenced letter. The Safety Evaluation Report (SER) on this amendment contains a discussion of the reed switches in the CEA position indication system. The SER discussion of the position reed switches indicates a two-inch interval between switches. This is not in agreement with the FSAR description and Technical Manuals which indicate a one and one-half inch spacing interval. The discrepancy has no material effect on the SER. All other aspects of the description of the Rod Position Indication System are as stated in the SER.

This correction is being provided to the Staff for information only. No action is requested or required.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

  
W. G. Council  
Senior Vice President

8408130316 840803  
PDR ADOCK 05000336  
P PDR

A001  
1/0