



GPU Nuclear Corporation  
Route 441 South  
P.O. Box 480  
Middletown, Pennsylvania 17057-0480  
(717) 944-7621  
Writer's Direct Dial Number:

(717) 948-8005

November 08, 1995  
C311-95-2463

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Gentlemen:


Subject: Three Mile Island Nuclear Station, Unit 1 (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289  
Completion of Actions Required by Generic Letter (GL) 89-10,  
"Safety-Related Motor-Operated Valve Testing and Surveillance"

This letter is in response to Generic Letter (GL) 89-10, "Safety-Related Motor-Operated Valve Testing and Surveillance," item (m), which requires licensees to notify the NRC in writing within 30 days after the actions described in the first paragraph of item (i) have been completed.

The TMI-1 GL 89-10 Motor Operated Valve (MOV) program design basis reviews, calculations and testing have been completed and the program description is being updated to reflect the work completed during the Cycle 11 Refueling (11R) Outage. Several valves have been modified to increase the available margins and torque switch settings for other valves have been changed to accommodate valve factors based on industry data. GPU Nuclear has confidence that the design basis capability of the MOV program valves has been demonstrated. This completes the GPU Nuclear response to GL 89-10 which includes a continuation of periodic testing in accordance with the MOV program.

Sincerely,

130069



J. Knubel  
Vice President and Director, TMI

ATTACHMENT  
MRK

cc: Administrator, Region I  
TMI-1 Senior Project Manager  
TMI Senior Resident Inspector

9511130286 951108  
PDR ADDCK 05000289  
P PDR

ADD 4


ATTACHMENT  
C311-95-2463

METROPOLITAN EDISON COMPANY  
JERSEY CENTRAL POWER AND LIGHT COMPANY  
PENNSYLVANIA ELECTRIC COMPANY  
GENERAL PUBLIC UTILITIES NUCLEAR CORPORATION

Three Mile Island Nuclear Station, Unit 1 (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289


Completion of Actions Required by Generic Letter (GL) 89-10

This letter is submitted in response to the NRC request to be notified of the completion of actions described in GL 89-10, "Safety-Related Motor-Operated Valve Testing and Surveillance." All statements contained in this response have been reviewed, and all such statements made and matter set forth therein are true and correct to the best of my knowledge.

  
J. Knubel  
Vice President and Director, TMI

Signed and sworn before me this

9th day of NOVEMBER, 1995.

  
Notary Public

