



Log # TXX-95278  
File # 10035  
Ref. # 10CFR50.54(f)  
GL 95-07

C. Lance Terry  
Group Vice President

November 6, 1995

U. S. Nuclear Regulatory Commission  
Attn.: Document Control Desk  
Washington, DC 20555-0001

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES) UNITS 1 AND 2  
DOCKET NOS. 50-445 AND 50-446  
RESPONSE TO GENERIC LETTER 95-07, "PRESSURE LOCKING AND THERMAL  
BINDING OF SAFETY RELATED POWER OPERATED GATE VALVES"

- REF: 1. Generic Letter 95-07, "Pressure Locking and Thermal Binding  
of Safety Related Power Operated Gate Valves," dated August  
17, 1995
2. TU Electric letter logged TXX-95263 from Mr. C.L. Terry to  
NRC dated October 16, 1995

Gentlemen:

On August 17, 1995, the NRC issued Generic Letter 95-07, "Pressure Locking and Thermal Binding of Safety Related Power Operated Gate Valves" (Reference 1). Pursuant to Section 182a of the Atomic Energy Act of 1954, as amended, and 10 CFR 50.54(f), TU Electric submitted a response (Reference 2) to the requested information and requested actions as stated in Generic Letter 95-07.

Via this letter TU Electric is providing the following clarification, with respect to the 90 day requested actions stated in Generic Letter 95-07.

Within 90 days of the date of the subject generic letter, TU Electric will perform and complete the following actions:

1. Perform a screening evaluation of the operational configurations of all safety-related power-operated (i.e., motor-operated, air-operated, and hydraulically operated) gate valves to identify those valves that are potentially susceptible to pressure locking or thermal binding; and
2. Document a basis for the operability of the potentially susceptible valves or, where operability cannot be supported, take action in accordance with individual plant Technical Specifications.


9511140094 951106  
PDR ADDOCK 05000445  
PDR

A056  
1/10

TXX-95278  
Page 2 of 2

If you have any questions, please contact Obaid Bhatti at (817) 897-5839.

Sincerely,



C. L. Terry

OB/ob

c - Mr. L. J. Callan, Region IV  
Resident Inspectors, CPSES  
Mr. T. J. Polich, NRR  
Mr. W. D. Johnson, Region IV