

Georgia Power Company
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Telephone 205 877 7122

C. K. McCoy
Vice President, Nuclear
Vogtle Project



March 17, 1992

ELV-03560
001335

Docket Nos. 50-424
50-425

TAC-M82914
M82915

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Gentlemen:

VOGTLE ELECTRIC GENERATING PLANT
REQUEST FOR ADDITIONAL INFORMATION
REGARDING CALCON SENSORS

Per our discussion with Mr. D. S. Hood, this is to confirm that the last failure of a diesel generator attributed to the Calcon sensors occurred on May 23, 1990, which was prior to the last enhancement to the calibration procedure.

Sincerely,

C. K. McCoy
C. K. McCoy

CKM/NJS/gmb

xc: Georgia Power Company
Mr. W. B. Shipman
Mr. M. Sheibani
NORMS

U. S. Nuclear Regulatory Commission
Mr. S. D. Ebnetter, Regional Administrator
Mr. D. S. Hood, Licensing Project Manager, NRR
Mr. B. R. Bonser, Senior Resident Inspector, Vogtle

9203230302 920317
PDR ADOCK 05000424
P PDR

ADD 1
1/0