



South Carolina Electric & Gas Company  
P.O. Box 88  
Jenkinsville, SC 29065  
(803) 345-4344

Gary J. Taylor  
Vice President  
Nuclear Operations

November 14, 1995  
RC-95-0184

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Attention: Mr. Stephen Dembek

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION (VCSNS)  
DOCKET NO. 50/395  
OPERATING LICENSE NO. NPF-12  
TECHNICAL SPECIFICATION CHANGE - TSP 940007  
MOTOR OPERATED VALVES THERMAL OVERLOAD  
PROTECTION AND BYPASS DEVICES

South Carolina Electric & Gas Company (SCE&G), acting for itself and as agent for South Carolina Public Service Authority, hereby requests an amendment to the Virgil C. Summer Nuclear Station (VCSNS) Technical Specifications (TS). This change is being submitted pursuant to 10 CFR 50.90.

The proposed change will remove the specification for Motor Operated Valves Thermal Overload Protection and Bypass Devices (3/4.8.4.2) to follow the guidance of the improved Westinghouse Standardized Technical Specifications.

The TS change request (TSCR) is contained in the following attachments:

- |                |  |
|----------------|--|
| Attachment I   | Description of Changes Chart<br>Marked-up Technical Specification Pages<br>Revised Technical Specification Pages |
| Attachment II  | Description of Amendment Request and the supporting<br>Safety Evaluation   |
| Attachment III | Description of Amendment Request and the associated<br>No Significant Hazards Evaluation                         |

This proposed TSCR has been reviewed and approved by both the Plant Safety Review Committee and the Nuclear Safety Review Committee.

I declare that these statements and matters set forth herein are true and correct to the best of my knowledge, information, and belief.




200104  
9511200180 951114  
PDR ADDCK 05000395  
P PDR

ADD 11

Should you have any questions, please call Mr. Jim Turkett at (803) 345-4047 at your convenience.

Very truly yours,

  
Gary J. Taylor

JT/GJT/dr  
Attachments (3)

c: J. L. Skolds (w/o Attachments)  
O. W. Dixon  
R. R. Mahan (w/o Attachments)  
R. J. White  
S. D. Ebnetter  
NRC Resident Inspector

J. B. Knotts Jr.  
M. K. Batavia  
J. I. Byrd  
Central File System  
RTS (TSP 950009)  
File (813.20)


STATE OF SOUTH CAROLINA :

: TO WIT :

COUNTY OF FAIRFIELD :

I hereby certify that on the 14<sup>th</sup> day of November 1995, before me, the subscriber, a Notary Public of the State of South Carolina in and for Richland County, personally appeared Gary J. Taylor, being duly sworn, and states that he is Vice President, Nuclear Operations of the South Carolina Electric & Gas Company, a corporation of the State of South Carolina, that he provides the foregoing response for the purposes therein set forth, that the statements made are true and correct to the best of his knowledge, information, and belief, and that he was authorized to provide the response on behalf of said Corporation.

WITNESS my Hand and Notarial Seal

  
Notary Public

My Commission Expires

My Commission Expires July 13, 2005

Date

### SCE&G -- Explanation of Changes

<u>PAGE</u>	<u>Affected Section</u>	<u>Bar #</u>	<u>Description of Change</u>	<u>Reason for Change</u>
INDEX IX	3/4.8.4	1	Remove "Motor-Operated Valves Thermal Overload Protection and Bypass Devices.....Page 3/4 8-18" from Section 3/4.8.4.	Due to removal of Section 3.8.4.2 from the VCSNS Technical Specifications.
	3/4.8.4	2	ReNUMBER "Circuit Protection Devices .....Page 3/4 8-22" to Page 3/4 8-23.	Amendment 102 moved Section 3/4.8.4.3 to page 3/4 8-23. The required change to the Index Page was inadvertently missed.
3/4 8-18	3.8.4.2	1	Remove	Follows guidance of NUREG 1431, Westinghouse MERITS Technical Specifications Section 3/4.8. (Motor-Operated Valves Thermal Overload Protection and Bypass Devices is not addressed in <u>W</u> MERITS TS.)
	4.8.4.2	2	Remove	Follows guidance of NUREG 1431, Westinghouse MERITS Technical Specifications Section 3/4.8.
3/4 8-19	Table 3.8-2	1	Remove	Follows guidance of NUREG 1431, <u>W</u> MERITS TS 3/4.8 and GL 91-08, "Removal of Component Lists from Technical Specifications".
3/4 8-20	Table 3.8-2	1	Remove	Follows guidance of NUREG 1431, <u>W</u> MERITS TS 3/4.8 and GL 91-08.
3/4 8-21	Table 3.8-2	1	Remove	Follows guidance of NUREG 1431, <u>W</u> MERITS TS 3/4.8 and GL 91-08.
3/4 8-22	Table 3.8-2	1	Remove	Follows guidance of NUREG 1431, <u>W</u> MERITS TS 3/4.8 and GL 91-08.
B 3/4 8-3	B3/4.8.4	1	Remove	To remove discussion on MOVs.