

Duke Power Company
Catawba Nuclear Generation Department
4800 Concord Road
York, SC 29745

WILLIAM R. MCCOLLUM, JR.
Vice President
(803) 831-3200 Office
(803) 831-3426 Fax



DUKE POWER

November 14, 1995

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Subject: Catawba Nuclear Station, Unit 2
Docket No. 50-414
Special Report
End of Cycle 7 Refueling Outage
Steam Generator Tube Inspection Report


Pursuant to Catawba Technical Specification 4.4.5.5, part a, the following information is submitted:

1. The following quantities of steam generator tubes were removed from service by plugging:

<u>Steam Generator</u>	<u>Number of Tubes Plugged</u>
A	10
B	2
C	5
D	6

For further information, please contact Devereux Tower at (803) 831-3419.

Very truly yours,


W. R. McCollum, Jr.
Vice President

DT/

ADD 11/0

U.S. Nuclear Regulatory Commission
November 14, 1995
Page 2

Attachments

xc: Mr. S. D. Ebnetter
Regional Administrator, Region II

Mr. Robert E. Martin, Project Manager
ONRR

Mr. Nick Economos, Inspector
Region II

Mr. R. J. Freudenberger
NRC Resident Inspector
Catawba Nuclear Station

U.S. Nuclear Regulatory Commission
November 14, 1995
Page 3

bxc: D. B. Mayes
Z. L. Taylor
J. S. Forbes
G. B. Swindlehurst
C. B. Cauthen
J. M. Baumann
L. A. Reed
ELL-EC050
Group File: CN-801.01
Master File: CN-801.01