



52-003

Westinghouse  
Electric Corporation

Energy Systems

Box 355  
Pittsburgh Pennsylvania 15230-0355

NTD-NRC-95-4597  
DCP/NRC0431  
Docket No.: STN-52-003

November 13, 1995

Mr. Dennis Crutchfield  
Director  
Division of Reactor Program Management  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: AP600 DESIGN CERTIFICATION REVIEW PRIORITIES CLARIFICATION

Dear Mr. Crutchfield:

You are aware that considerable effort is being expended to define the federal budgets for fiscal year 1996, that a federal budget has not yet been established and that the government is working on a continuing resolution basis. Since the AP600 design certification program is funded, in part, by the Department of Energy, Westinghouse does not know at this time, precisely the resources that will be available to support the AP600 design certification program this fiscal year.

During our resource planning meeting on October 12, 1995, the staff provided Westinghouse with an estimate of the resources needed to complete the design certification review up to the final safety evaluation report preparation. Westinghouse has reviewed that input and has established the following priorities that will result in the most efficient utilization of resources for the AP600 design certification review for FY96.

As previously mentioned, the most immediate need continues to be completion of the supplemental draft safety evaluation report that addresses the acceptability of the testing program, the validation and verification of the computer codes and the application of the safety analysis codes to the AP600 design. Completion of this activity will ensure that there are no modifications to the AP600 design necessary to compensate for difficulties encountered as a part of the safety analysis calculation review. This activity includes the review of the NOTRUMP, LOFTRAN, WCOBRA/TRAC long term cooling WGOthic and the WCOBRA/TRAC code applicability document as well as the requisite ACRS meetings.

Progress has been made in implementing the path to resolution for Regulatory Treatment of Nonsafety Systems. Presently the focus is on how the uncertainty in the thermal hydraulic computer codes would affect the determination of the success criteria for the probabilistic risk assessment. This activity, along with a review of the revised AP600 level 1 probabilistic risk assessment, is essential to determining how regulatory control will be applied to the nonsafety systems in the AP600 that were safety related systems in conventional plant designs. The post-72 hour and adverse systems interaction subissues need to also be worked as a part of this review. A number of design related activities depend on resolution of this issue. Westinghouse will submit the PRA insights and fire PRA for NRC review.

220027

2623A

9511270225 951113  
PDR ADOCK 05200003  
A PDR

NRC FILE CENTER COPY

E004110

November 13, 1995

The review of the safety system function, design and performance (Chapters 6, 7 and 15) is necessary to finalize a number of the other design certification review activities, such as support system design, initial test program and the inspections, tests, analyses and acceptance criteria (ITAAC).

While the final ITAAC cannot be developed until the system design review is completed, it is prudent that Westinghouse receive staff feedback on the pilot ITAAC that are being developed for several sample systems. This feedback will be factored into the final ITAAC development program which will be initiated once the design of the systems is assured.


Westinghouse is continuing to develop responses to the NRC letters concerning the classification of proprietary information in the AP600 Standard Safety Analysis Report (SSAR), PRA. responses to NRC requests for additional information and presentation material. This activity will be completed to support NRC requirements and to allow Westinghouse to initiate development of the AP600 Design Control Document.

The requests for additional information on the severe accident mitigation design alternatives (SAMDAs) should be completed and transmitted to Westinghouse. The MELCOR, hydrogen control, in-vessel retention and shutdown risk areas of Chapter 19 should be brought to closure to assure that any impacts on the design are accounted for in a timely manner.

Providing a near term focus on these areas will optimize the use of resources for both Westinghouse and the NRC staff.

Based on input received from your staff at our October 12, 1995 review meeting, efforts in other areas of the AP600 review should formally document the status of the review based on documentation, submittals and related application materials supplied by Westinghouse. Westinghouse recognizes that the schedule associated with this approach will depend on timing of our submittals and will extend beyond the dates in SECY-94-117. Westinghouse and the NRC are in the process of working together to develop the logic and schedule to complete the AP600 review. Westinghouse also recognizes the estimated cost of the NRC review activities will depend on timing the review tasks for maximum effectiveness and may increase beyond the estimates provided by the NRC on October 12, 1995.

Please contact me if you require further information concerning these review priorities.



Brian A. McIntyre, Manager  
Advanced Plant Safety and Licensing

/nja

cc: W. T. Russell - NRC  
H. J. Bruschi - W  
N. J. Liparulo - W