

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: APRIL 1992
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

OPERATING STATUS

1. Unit Name: FITZPATRICK
2. Reporting Period: 920301 - 920331
3. Licensed Thermal Power (MW): 2436
4. Nameplate Rating (Gross MWE): 883
5. Design Electrical Rating (Net MWE): 816
6. Maximum Dependable Capacity (Gross MWE) 807
7. Maximum Dependable Capacity (Net MWE) 780

NOTES:

8. If changes occur in capacity ratings (Items 3-7) since last report, give reasons: _____
9. Power level to which restricted, if any (Net MWE): _____
10. Reasons for restrictions, if any: _____

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. Hours in Reporting Period:	744.0	2184.0	146210.0
12. Number of Hours Reactor was Critical:	0	0	104831.4
13. Reactor Reserve Shutdown Hours:	0	0	0
14. Hours Generator On-Line:	0	0	101731.2
15. Unit Reserve Shutdown Hours:	0	0	0
16. Gross Thermal Energy Generated (MWH):	0	0	223974910.0
17. Gross Electrical Energy Generated (MWH):	0	0	76322860.0
18. Net Electrical Energy Generated (MWH):	0	0	73269365.0
19. Unit Service Factor:	0	0	69.6
20. Unit Availability Factor:	0	0	69.6
21. Unit Capacity Factor (using MDC Net):	0	0	64.6
22. Unit Capacity Factor (using DER Net):	0	0	61.4
23. Unit Forced Outage Rate:	100.0	100.0	14.4

24. Shutdowns scheduled over next 6 months (type, date, and duration of each):
Refuel outage commenced January 11, 1992.

5. If shutdown at end of report period, estimated date of start-up: May 15, 1992

26. Units in Test Status (prior to commercial operation):
- | | FORECAST | ACHIEVED |
|----------------------|----------|----------|
| Initial Criticality | _____ | _____ |
| Initial Electricity | _____ | _____ |
| Commercial Operation | _____ | _____ |

9204060147 920331
PDR ADOCK 05000333
R PDR

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
AVERAGE DAILY UNIT POWER LEVEL

REPORT MONTH: MARCH 1992

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: APRIL 1992
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	0
16	0		

SUMMARY: The FitzPatrick Plant remained shutdown for the entire reporting period.

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
UNIT SHUTDOWNS REPORT

REPORT MONTH: MARCH 1992

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: APRIL 1992
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

NO.	DATE	TYPE	D U R A T I O N	R E A S O N	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT	S Y C S O T D E E M	C O M P O D N E E N T	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
2	920301	S	744	C	1	N/A	N/A	N/A	S/D for Refueling Commenced 920110 (Cumulative Hours 1937).

1 F: FORCED S: SCHEDULED	2 REASON: A. EQUIPMENT FAILURE (EXPLAIN) B. MAINTENANCE OR TEST C. REFUELING D. REGULATORY RESTRICTION E. OPERATOR TRAINING AND LICENSE EXAMINATION F. ADMINISTRATIVE G. OPERATIONAL ERROR (EXPLAIN) H. OTHER (EXPLAIN)	3 METHOD: 1. MANUAL 2. MANUAL SCRAM 3. AUTOMATIC SCRAM 4. CONTINUED 5. REDUCED LOAD 9. OTHER	4 EXHIBIT G - INSTRUCTIONS FOR PREPARATION OF DATA ENTRY SHEETS FOR LICENSEE EVENT REPORT (LER) FILE (NUREG-0161)
---------------------------------------	---	--	--

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
NARRATIVE SUMMARY OF OPERATING EXPERIENCE

REPORT MONTH: MARCH 1992

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: APRIL 1992
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

The FitzPatrick Plant remained shutdown for this entire reporting period.

The major work items during this reporting period were:

- Reduction of plant combustible loading
- Fire Protection System corrective maintenance
- Core Spray System piping replacement
- Residual Heat Removal System maintenance
- Emergency Diesel Generator maintenance