

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
 )  
Omaha Public Power District ) Docket No. 50-285  
(Fort Calhoun Station )  
Unit No. 1) )

APPLICATION FOR AMENDMENT  
OF  
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission ("the Commission"), Omaha Public Power District, holder of Facility Operating License No. DPR-40, herewith requests that the Technical Specifications set forth in Appendix A to that License be amended to add a Limiting Condition for Operation and surveillance test for safety related inverters and delete nonsafety related instrument buses.

The proposed changes in Technical Specifications are provided in Attachment A to this Application. A Discussion, Justification and No Significant Hazards Consideration Analysis, which demonstrates that the proposed changes do not involve significant hazards consideration, is appended in Attachment B. The proposed changes in specifications would not authorize any change in the types or any increase in the amounts of effluents that will be released, or a change in the authorized power level of the facility.

WHEREFORE, Applicant respectfully requests that Specifications 2.7 and 3.7 of Appendix A to Facility Operating License No. DPR-40 be amended in the form attached hereto as Attachment A.

A copy of this Application, including its attachments, has been submitted to the Director - Environmental Health Division, State of Nebraska, as required by 10 CFR 50.91.

OMAHA PUBLIC POWER DISTRICT

By *Mr. Gary Hots*  
Vice President

Subscribed and sworn to before me this 16th day of November, 1995.

*Theresa Petersen*  
Notary Public



U.S. Nuclear Regulatory Commission  
LIC-95-0218

## ATTACHMENT A