

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Turkey Point Unit 4										DOCKET NUMBER (2) 0 5 0 0 0 2 5 1										PAGE (3) 1 OF 1																													
TITLE (4) Engineered Safety Feature Actuation - Safety Injection Pump Actuation																																																	
EVENT DATE (5)										LER NUMBER (6)										REPORT DATE (7)										OTHER FACILITIES INVOLVED (8)																			
MONTH			DAY			YEAR			YEAR			SEQUENTIAL NUMBER			REVISION NUMBER			MONTH			DAY			YEAR			FACILITY NAMES										DOCKET NUMBER(S)												
																											N/A										0 5 0 0 0												
0 7			1 6			8 4			8 4			0 1			5			0 0			0 8			1 0			8 4			N/A										0 5 0 0 0									
OPERATING MODE (9) N										THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)																																							
POWER LEVEL (10) 0.00										20.402(b)										20.405(c)										<input checked="" type="checkbox"/> 50.73(a)(2)(iv)										73.71(b)									
										20.405(a)(1)(i)										50.36(c)(1)										50.73(a)(2)(v)										73.71(c)									
										20.405(a)(1)(ii)										50.36(c)(2)										50.73(a)(2)(vi)										OTHER (Specify in Abstract below and in Text, NRC Form 366A)									
										20.405(a)(1)(iii)										50.73(a)(2)(i)										50.73(a)(2)(vii)(A)																			
										20.405(a)(1)(iv)										50.73(a)(2)(ii)										50.73(a)(2)(vii)(B)																			
20.405(a)(1)(v)										50.73(a)(2)(iii)										50.73(a)(2)(ix)																													
LICENSEE CONTACT FOR THIS LER (12)																																																	
NAME Randall D. Hart, Licensing Engineer																				TELEPHONE NUMBER 3 0 5 2 4 5 - 2 9 1 0																													
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																																																	
CAUSE			SYSTEM			COMPONENT			MANUFACTURER			REPORTABLE TO NRC			CAUSE			SYSTEM			COMPONENT			MANUFACTURER			REPORTABLE TO NRC																						
SUPPLEMENTAL REPORT EXPECTED (14)																				EXPECTED SUBMISSION DATE (15)										MONTH DAY YEAR																			
<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)																				<input checked="" type="checkbox"/> NO																													

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single space typewritten lines) (16)

On July 16, 1984, while at cold shutdown conditions, Unit 4 experienced an unexpected start of the 4A high head safety injection (HHSI) pump. The root cause was determined to stem from construction personnel inadvertently striking the local control switch on the 4A breaker cubicle. Construction personnel were installing scaffolding in the vicinity of the breaker and due to the limited space between the scaffolding and switchgear, they brushed against the local switch starting the pump. No Engineered Safety Feature Actuation Signal (ESFAS) was present, therefore, the valves did not line up and no flow was delivered to the core. Immediate corrective actions included: 1) the 4A HHSI pump was stopped and in an attempt to verify the root cause, plant personnel recreated the events at the breaker cubicle which indeed started the pump, and 2) construction personnel were cautioned about the importance of being careful when working in the vicinity of electrical breakers. The health and safety of the public were not affected. Similar occurrences: LER 250-84-007, LER 250-84-012, and LER 251-84-006.

8408170191 840810
PDR ADOCK 05000251
S PDR

August 10 1984
PNS-LI-84-284

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:

Re: Reportable Event 84-15
Turkey Point Unit 4 50-251
Date of Event: July 16, 1984
Engineered Safety Feature Actuation-
Safety Injection Pump Actuation

The attached Licensee Event Report is being submitted pursuant to the requirements of 10 CFR to provide notification of the subject event.

Very truly yours,

for J. W. Williams, Jr.
J. W. Williams, Jr.
Group Vice President
Nuclear Energy

JWW/PLP/js

Attachment

cc: J. P. O'Reilly, Region II, USNRC
Harold F. Reis, Esquire
File 933.1 TP

IE22
1/1