

Omaha Public Power District
444 South 16th Street Mall
Omaha, Nebraska 68102-2247
402/636-2000

April 3, 1992
LIC-92-127

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Mail Station: P1-137
Washington, DC 20555

Reference: Docket No. 50-285

Gentlemen:

SUBJECT: Steam Generator Tube Plugging Report

Fort Calhoun Station's (FCS) Technical Specification 3.17(5)(i) states, "Following each in-service inspection of steam generator tubes, the number of tubes plugged in each steam generator shall be reported to the Commission within 30 days". On March 7, 1992, during the Thirteenth Refueling Outage at FCS, eddy current testing was completed. As a result of this testing, and in accordance with Technical Specification 3.17(5)(i), Omaha Public Power District reports that no steam generator tubes required plugging. To date, Steam Generator (S/G) A has 55 plugged tubes and S/G B has 54 plugged tubes.

If you should have any questions, please contact me.

W. G. Gates

W. G. Gates
Division Manager
Nuclear Operations

WGG:lah

c: LeBeouf, Lamb, Leiby & MacRae
R. D. Martin, NRC Regional Administrator, Region IV
D. L. Wigginton, NRC Senior Project Manager
S. D. Bloom, NRC Project Engineer
R. P. Mullikin, Senior Resident Inspector

9204080119 920403
PDR ADDCK 05000285
P PDR