

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)
Washington Nuclear Plant - Unit 2DOCKET NUMBER (2)
0 5 0 0 0 3 9 7 1 OF 0 2TITLE (4)
Missed Fire Watch During Unusual EventEVENT DATE (6)
MONTH DAY YEAR
0 7 2 8 8 4 8 4
LER NUMBER (6)
SEQUENTIAL NUMBER REVISION NUMBER
0 7 6 0 0 0 8 0 8 8 4
REPORT DATE (7)
MONTH DAY YEAR
0 7 2 8 8 4
OTHER FACILITIES INVOLVED (8)
FACILITY NAMES DOCKET NUMBER(S)
0 5 0 0 0 0 0 0THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 8. (Check one or more of the following) (11)
OPERATING MODE (9) 4
POWER LEVEL (10) 0 0 0
20.402(b) 20.405(e) 50.73(a)(2)(iv) 73.71(b)
20.405(a)(1)(i) 50.38(a)(1) 50.73(a)(2)(v) 73.71(c)
20.405(a)(1)(ii) 50.38(a)(2) 50.73(a)(2)(vi) OTHER (Specify in Abstract below and in Text, NRC Form 366A)
20.405(a)(1)(iii) X 50.73(a)(2)(vii) 50.73(a)(2)(viii)(A)
20.405(a)(1)(iv) 50.73(a)(2)(viii)(B)
20.405(a)(1)(v) 50.73(a)(2)(ix)LICENSEE CONTACT FOR THIS LER (12)
NAME R. L. Koenigs, Compliance Engineer
TELEPHONE NUMBER 5 0 9 3 7 7 1 2 5 0 1
Ext. 2279COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)
CAUSE SYSTEM COMPONENT MANUFACTURER REPORTABLE TO NRC
X I C - - - - - NSUPPLEMENTAL REPORT EXPECTED (14)
X YES (If yes, complete EXPECTED SUBMISSION DATE) NO
EXPECTED SUBMISSION DATE (15)
MONTH DAY YEAR

ABSTRACT (Limit to 400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

During the declaration of an Unusual Event subsequent to finding a possible bomb, an hourly fire watch tour was not performed. The tours resumed immediately upon termination of the unusual event status and only one tour was omitted.

8408200132 840808
PDR ADOCK 05000397
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104

EXPIRES 8/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
Washington Nuclear Plant - Unit 2	0 5 0 0 0 3 9 7 8 4	-	0 7 1 6	-	0 0 0 1 2 OF 0 1 2	

TEXT (If more space is required, use additional NRC Form 386A's) (17)

Plant Conditions

- a) Reactor Power - 0%
b) Operational Mode - 4

Event

On 7/28/84 a suspected bomb was found in the Plant and an Unusual Event declared. Response procedures for this event direct all personnel outside the Control Room to report to a central location. This precluded the fire watch from making the scheduled hourly tour required by Technical Specifications 3.7.6.2 and 3.7.7.

Immediate Corrective Action

Upon termination of the Unusual Event, the fire watch tours resumed as scheduled.

Long Term Corrective Action

This is considered an appropriate response to the situation, with emergency response procedures taking precedence. No further action is contemplated. The Unusual Event was reported under Security Event Report SER #84-003.

Safety Significance

There is no safety significance attached to the missed fire watch tour as no fire existed and fire brigade response was still available. Also, only one tour was missed and normal fire watch tours were immediately recommenced upon termination of the Unusual Event.

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket No. 50-397

August 8, 1984


Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: NUCLEAR PLANT NO. 2
LICENSEE EVENT REPORT NO. 84-076

Dear Sir:

Transmitted herewith is Licensee Event Report No. 84-076 for WNP-2 Plant. This report is submitted in response to the report requirements of 10CFR50.73 and discusses the item of reportability, corrective action taken, and action taken to preclude recurrence.

Very truly yours,



J. D. Martin (M/D 927M)
WNP-2 Plant Manager

JDM:mm

Enclosure:

Licensee Event Report No. 84-076

cc: Mr. John B. Martin, NRC - Region V
Mr. A. D. Toth, NRC - Site (901A)
Ms. Dottie Sherman, ANI
INPO Records Center - Atlanta, GA

IE22
11