



**Florida
Power**
CORPORATION

H. Silver

August 8, 1984
3F0884-03

Director of Nuclear Reactor Regulation
Attention: George W. Rivenbark, Acting Chief
Operating Reactors Branch #4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
NUREG-0737, Item II.B.2
Plant Shielding

Dear Sir:

At the meeting of February 15, 1984, at Crystal River Unit 3, Florida Power Corporation updated the NRC on the status of selected NUREG-0737 items.

During the meeting, the question was asked if the scenario of boron precipitation decay heat system flow into the reactor hot leg is covered in the emergency operating procedures. FPC responded by ensuring that this concern would be covered. Operating Procedure OP-404 titled "Decay Heat Removal System" addresses this concern.

Sincerely,

G. R. Westafer

G. R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management

EMG/feb

cc: Mr. J. P. O'Reilly
Regional Administrator, Region II
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, GA 30323

8408200311 840808
PDR ADDCK 05000302
F PDR

A046
1/0