



TITUS® PRODUCTS

Division of Philips Industries Inc.

990 Security Row
Richardson, Texas 75081
214-699-1030

Manufacturing Quality Components for Better Building.

August 7, 1984

Palo Verde Nuclear Generating Station
Units I, II, and III
P.O. Box 215
Buckeye, Arizona 85326

Attention: Robert Strait
Project Engineer

Subject: Model 272 Grille, Tension Wires

It has recently come to our attention that some of the tension wires used for adjustment of the blades on Grille Model 272 will not remain in place when the blades are closed.

A review is being conducted for the total number of grilles supplied and will be forthcoming identifying the total scope.

Testing is being conducted to identify rework methods to be utilized. Upon completion Titus will schedule personnel to complete rework.

Titus Products has notified the Nuclear Regulatory Commission of this situation in accordance with the requirements of 10 CFR Part 21.

We will be contacting you with further information and making arrangements to rework the subject grilles.

Sincerely,

TITUS PRODUCTS DIVISION

Steven L. Schneider
President

cc: Ned Ryan
Marv DeHart
Richard Yarges

8408200333 840807
PDR ADDCK 05000528
S PDR

IE 19
1/0