



**Wisconsin  
Electric**  
POWER COMPANY

231 W. Michigan, P.O. Box 2046, Milwaukee, WI 53201

(414) 271-2345

VPNPD-92-147  
NRC-92-041

10 CFR 50.73

April 9, 1992

U. S. NUCLEAR REGULATORY COMMISSION  
Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

Gentlemen:

DOCKET 50-301  
LICENSEE EVENT REPORT 92-001-00  
IMPROPER CALIBRATION OF ONE CHANNEL  
OF OVER-TEMPERATURE DELTA T, RESULTING  
IN A TECHNICAL SPECIFICATION VIOLATION  
POINT BEACH NUCLEAR PLANT, UNIT 2

Enclosed is Licensee Event Report 92-001-00 for Point Beach Nuclear Plant, Unit 2. This report is provided in accordance with 10 CFR 50.73(a)(2)(i), "Any operation or condition prohibited by the plant's Technical Specifications." This report describes the improper calibration of one channel of over-temperature delta T, which resulted in a violation of the minimum operable channels and minimum degree of redundancy.

This report was initially submitted on March 17, 1992, but it was improperly numbered as Licensee Event Report 92-003-00. This submittal is being made to rectify that error, and we request that LER 92-003-00 be withdrawn and replaced by 92-001-00.

Please contact us if there are any questions.

Sincerely,

James J. Zach  
Vice President  
Nuclear Power

Enclosure

Copies to NRC Resident Inspector  
NRC Regional Administrator

9204140001 920409  
PDR ADDCK 05000301  
S PDR