

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Dresden Nuclear Power Station Unit 3 DOCKET NUMBER (2) 0 5 0 0 0 2 4 9 PAGE (3) 1 OF 0 2

TITLE (4) East LPCI Submarine Door Found Open

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)	
0	7	1	6	8	4	8	4	0	0	5	0
0	7	1	6	8	4	8	4	0	0	5	0
0	7	1	6	8	4	8	4	0	0	5	0

OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 8: (Check one or more of the following) (11)									
POWER LEVEL (10)	01010	20.402(b)		20.406(a)		80.73(a)(2)(iv)		73.71(b)			
		20.406(a)(1)(i)		80.36(a)(1)		80.73(a)(2)(v)		73.71(c)			
		20.406(a)(1)(ii)		80.36(a)(2)		80.73(a)(2)(vi)		OTHER (Specify in Abstract below and in Text, NRC Form 366A)			
		20.406(a)(1)(iii)		80.73(a)(2)(i)		80.73(a)(2)(vii)(A)					
		20.406(a)(1)(iv)		80.73(a)(2)(ii)		80.73(a)(2)(viii)(B)					
		20.406(a)(1)(v)		80.73(a)(2)(iii)		80.73(a)(2)(ix)					

LICENEE CONTACT FOR THIS LER (12)
NAME Mark Leahy (X-422) TELEPHONE NUMBER 811 594 121-1 291210

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)										
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	
A										

SUPPLEMENTAL REPORT EXPECTED (14)
YES (If yes, complete EXPECTED SUBMISSION DATE) X NO
EXPECTED SUBMISSION DATE (15)
MONTH DAY YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

With the unit shutdown for high pressure turbine repair, the east LPCI corner room submarine door was found open in violation of the Technical Specifications. Safety significance was minimal, since LPCI and core spray were not required to be operable and the door was immediately closed. The door had been left open by Stationmen working in the area earlier. It was emphasized to the Stationmen that the Technical Specifications require that these doors remain closed. An annunciator will be installed indicating that the door has been opened on all four submarine doors between the LPCI/core spray pump vaults and the torus basements.

8408210104 840813
PDR ADOCK 05000249
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES 8/31/85

FACILITY NAME (1) Dresden Nuclear Power Station Unit 3	DOCKET NUMBER (2) 0 5 0 0 0 2 4 9 8 4 — 0 0 5 — 0 0 0 2 OF 0 2	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		

TEXT (If more space is required, use additional NRC Form 365A's) (17)

With the unit shutdown for turbine repair, the east LPCI corner room submarine door was found open. Safety significance was minimal since LPCI and core spray were not required to be operable. Previous similar occurrence was reported by R.O. 84-006 on Docket #050237.

A breathing air hose was found passing through the east LPCI corner room submarine door. The hose was left there by Stationmen working in the area earlier. The hose was removed and the door closed. It was emphasized to the Stationmen that the Technical Specifications require that this door remain closed.

To ensure that these four doors remain closed except for passage, annunciators will be installed, informing the control room operator that a door has been opened. These annunciators will be installed by September, 1985.



Commonwealth Edison

Dresden Nuclear Power Station

R.R. #1

Morris, Illinois 60450

Telephone 815/942-2920

August 13, 1984

DJS Ltr #84-802

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Licensee Event Report #84-005-0, Docket #050249 is being submitted as required by Technical Specification 6.6, NUREG 1022 and 10 CFR 50.73 (a)(2)(i)(B).

D.J. Scott
Station Superintendent
Dresden Nuclear Power Station

DJS/kjl

Enclosure

cc: J.G. Keppler, Regional Administrator, Region III
Filer/NRC
File/Numerical

IE22

11