

Georgia Power Company
333 Piedmont Avenue
Atlanta, Georgia 30308
Telephone 404 526-6526

Mailing Address:
Post Office Box 4545
Atlanta, Georgia 30302

L. T. Gucwa
Manager Nuclear Engineering
and Chief Nuclear Engineer



NED-84-440

August 16, 1984

Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

NRC DOCKET 50-366
OPERATING LICENSE NPF-5
EDWIN I. HATCH NUCLEAR PLANT UNIT 2
CORRECTED PAGES - PROPOSED TECHNICAL SPECIFICATIONS
ON CONTAINMENT ISOLATION VALVES

Gentlemen:

Our August 6, 1984, letter requested an amendment to the Plant Hatch Unit 2 Technical Specifications. The proposed change would revise the stated actuation signals for certain containment isolation valves in order to be consistent with the original design of the unit. However, the revised pages submitted inadvertently omitted one of the two containment isolation signals to the subject valves. Both signals are available to actuate the valves, as discussed in our August 10, 1984, letter which provided additional information regarding our request. The attached pages contain the proposed amendment as intended in our original request. The drywell pressure isolation signal remains unchanged, and the reactor water level isolation signal is changed from RPV level 3 to RPV level 1.

Very truly yours,

L. T. Gucwa

RDB/mb

Enclosures

xc: J. T. Beckham, Jr.
H. C. Nix, Jr.
J. P. O'Reilly (NRC- Region II)
Senior Resident Inspector

8408210175 840816
PDR ADOCK 05000366
P PDR

Acc
11