

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES		
VALVE FUNCTION AND NUMBER	VALVE GROUP (a)	ISOLATION TIME (Seconds)
A. Automatic Isolation Valves (Continued)		
6. Containment Spray Isolation Valves		
2E11-F016 A(b) and B(b)	*	10
2E11-F028 A(b) and B(b)	*	24
7. RHR Heat Exchanger Drain Isolation Valves		
2E11-F011 A and B	*	20
2E11-F026 A and B	*	20
8. Drywell-to-Torus Differential Pressure System Isolation Valves		
2T48-F209	12	5
2T48-F210	12	5
2T48-F211	12	5
2T48-F212	12	5
9. HPCI Steam Line Isolation Valves		
2E41-F002	3	50
2E41-F003	3	50

(a) See Specification 3.3.2, Table 3.3.2-1, for isolation signals that operate each valve group

(b) May be opened on an intermittent basis under administrative control

*Closes upon actuation of the LPCI mode of RHR via a high drywell pressure signal (see item 2.a of Table 3.3.3-1) or a Low Low Low (Level 1) signal from 2B21-N691A,B,C,D (see item 2.b of Table 3.3.3-1).

8408210235 840816
PDR ADOCK 05000366
PDR

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES		
VALVE FUNCTION AND NUMBER	VALVE GROUP (a)	ISOLATION TIME (Seconds)
A. Automatic Isolation Valves (Continued)		
21. Core Spray System Flow Test Line Isolation Valves		
2E21-F015 A	*	50
2E21-F015 B	*	50
22. Suppression Pool Vent and Purge System Isolation Valves		
2T48-F338	10	5
2T48-F339	10	5
2T48-F318	10	5
2T48-F326	10	5
23. RHR Shutdown Cooling Suction Isolation Valves		
2E11-F008	11	24
24. RPV Head Spray Isolation Valve		
2E11-F023	11	20

(a) See Specification 3.3.2, Table 3.3.2-1, for isolation signals that operate each valve group

*Closes upon actuation of Core Spray via a high drywell pressure signal (see item 1.b of Table 3.3.3-1) or a Low Low Low (Level 1) signal from 2B21-N691A,B,C,D (see item 1.a of Table 3.3.3-1).