

3150-0011

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

PHONE: (717) 542-3239

NRC USE ONLY

IE 22



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

August 2, 1984

Dr. Thomas E. Murley
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-046/03X-1
ER 100450 FILE 841-23
PLA-2266

Docket No. 50-387
License No. NPF-14

Dear Dr. Murley:

Attached is Licensee Event Report 83-046/03X-1. This event was originally determined to be reportable per Technical Specification 6.9.1.9.b, in that during the performance of a monthly surveillance test on the 'D' Diesel Generator, a fuel oil leak developed at the 1L cylinder causing the diesel to be shutdown. Revision 1 of the Licensee Event Report is provided for additional information concerning actions that were taken as a result of this event.

H.W. Keiser
Superintendent of Plant - Susquehanna

öLW/pjg

cc: Mr. R.H. Jacobs
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

IE22
11