

Georgia Power Company  
333 Piedmont Avenue  
Atlanta, Georgia 30308  
Telephone 404 526 3195

Mailing Address:  
40 Inverness Center Parkway  
Post Office Box 1295  
Birmingham, Alabama 35201  
Telephone 205 868 5581

W. G. Hairston, III  
Senior Vice President  
Nuclear Operations

the Southern Electric System

HL-2142  
003205

April 16, 1992

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

PLANT HATCH - UNIT 2  
NRC DOCKET 50-366  
OPERATING LICENSE NPF-5  
PRIMARY CONTAINMENT HARDENED VENT  
NRC TAC No. M74870

Gentlemen:

The purpose of this letter is to document verbal agreements recently reached between GPC and NRC/NRR staff personnel regarding technical questions on the physical installation of the Plant Hatch Unit 2 containment hardened vent (reference Generic Letter 89-16). Specifically, two issues have been resolved. First, the new primary containment vent path will not be considered a secondary containment by-pass leakage path and thus, leakage barriers in the new vent pipe (valves and rupture disc) will not be subject to leakage rate testing requirements similar to those prescribed by 10 CFR 50, Appendix J. Note that the hardened vent pipe would be isolable under severe accident conditions (pressure and temperature) following use of the vent by closing the new valve installed upstream of the rupture disc. However, it is likely that leakage past this valve would be in excess of that typically allowed for PCIVs. GPC believes the radiological consequences of any such leakage would be trivial compared to the potential consequences of use of the hardened vent.

Second, Standby Gas Treatment (SBGT) System piping outboard of the second primary containment isolation valve will be reclassified from ASME Section III, Class II to Class III, and the new primary containment hardened vent system will be installed to Class III standards. A simplified sketch showing the location of the hardened vent and pipe classification boundaries is enclosed for your information.

210063  
9204210368 920416  
PDR ADCK 05000366  
P PDR

April

U.S. Nuclear Regulatory Commission  
April 16, 1992  
Page Two

Should you have any questions, please contact this office.

Sincerely,



W. G. Hairston, III

SJB/cr

Enclosure

cc: Georgia Power Company  
Mr. H. L. Sumner, General Manager - Nuclear Plant  
NORMS

U.S. Nuclear Regulatory Commission, Washington, D.C.  
Mr. K. Jabbour, Licensing Project Manager - Hatch

U.S. Nuclear Regulatory Commission, Region II  
Mr. S. D. Ebnetter, Regional Administrator  
Mr. L. D. Wert, Senior Resident Inspector - Hatch

# PLANT E. I. HATCH PROPOSED TORUS HARDENED VENT MODIFICATION

