



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

August 15, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Byron Station Units 1 and 2
Technical Specifications
NRC Docket Nos. 50-454/455

Reference (a): December 16, 1983 memorandum from
Cecil O. Thomas

Dear Mr. Denton:

This is to provide additional comments regarding the proof and review version of the Byron Unit 1 Technical Specifications that were distributed by Reference (a).

References to the three loop operation during Modes 1, 2, 3 and 4 should be removed from the Technical Specifications. Because we do not have supporting Westinghouse analyses to do so, three loop operation will not be used during these modes of operation. Additionally, our operating personnel have not been trained to operate in these modes.

Very truly yours

E. Douglas Swartz
Nuclear Licensing Administrator

cc: RIII Inspector - Byron

L. N. Olshan - LB 1

9081N

8408220368 840815
PDR ADDCK 05000454
A PDR

Boo!
1/0