



Log # TXX-95306
File # 916 (2.0)
10010
Ref. # 10CFR50.90
10CFR50.59

C. Lance Terry
Group Vice President

December 15, 1995

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
Docket NOS. 50-445 AND 50-446
SUBMITTAL OF CHANGES IN BASES SECTION 2.2.1
FOR UNIT 1 AND UNIT 2 TECHNICAL SPECIFICATIONS

Gentlemen:

The purpose of this letter is to transmit the enclosed approved changes to the BASES Section 2.2.1 of the CPSES Unit 1 and Unit 2 Technical Specifications.

The changes delete the specific statements regarding the response time for the RCP Undervoltage (1.2 seconds) and Underfrequency (0.3 seconds) from Technical Specifications BASES 2.2.1.

TU Electric has determined via the 10CFR50.59 process that these changes do not involve an unreviewed safety question. The changes were incorporated in the Unit 1 and Unit 2 Technical Specifications on December 12, 1995.

Enclosure 1 includes a detailed description and a marked up copy of the affected Technical Specifications (NUREG-1468).

TU Electric requests that the NRC incorporate these changes in a future license amendment for CPSES Unit 1 and Unit 2.

180043


9512180165 951215
PDR ADDOCK 05000445
P PDR

D229

Should you have any questions, please contact Mr. Manu Patel at
(214) 812-8298.

Sincerely,

C. L. Terry

By: 
D. R. Woodlan
Docket Licensing Manager

MCP/grp

Enclosure: 1. Technical Specifications BASES, 2.2.1

c - Mr. L. J. Callan, Region IV
Mr. W. D. Johnson, Region IV
Resident Inspectors, CPSES
Mr. T. J. Polich, NRR

Mr. Arthur C. Tate
Bureau of Radiation Control
Texas Department of Public Health
1100 West 49th Street
Austin, Texas 78704