



*Southern California Edison Company*

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92574-0128

December 14, 1995

WALTER C. MARSH  
MANAGER OF NUCLEAR REGULATORY AFFAIRS

TELEPHONE  
(714) 368-7501

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362  
Monthly Operating Reports for November 1995  
San Onofre Nuclear Generating Station, Units 2 and 3

Technical Specification 6.9.1.10 of Facility Operating Licenses NPF-10 and NPF-15 for the San Onofre Nuclear Generating Station, Units 2 and 3, respectively, requires Edison to provide a Monthly Operating Report for each Unit, which includes: routine operating statistics and shutdown experience; all challenges to safety valves; any changes to the Offsite Dose Calculation Manual (ODCM); and any major changes to the radioactive waste treatment system. All covered activities are reported monthly, except for ODCM changes, which are reported within 90 days from the time the changes are effective.

This letter transmits the November 1995 Monthly Operating Reports for Units 2 and 3, respectively. There were no challenges to safety valves, no major changes to the Units 2 and 3 radioactive waste treatment systems, and no changes to the ODCM during the reporting period.

As a separate item, Edison noted an omission in the May, 1995, Unit 2 Monthly Operating report. The value for "Number of Hours Reactor was Critical" omitted a few days of non-power operation. Attachment III to this letter provides a corrected page for May, and corrected pages for the months thereafter.

If you require any additional information, please let me know.

Sincerely,

Enclosures

cc: L. J. Callan, Regional Administrator, NRC Region IV  
J. E. Dyer, Director, Division of Reactor Projects, NRC Region IV  
K. E. Perkins, Jr., Director, Walnut Creek Field Office, NRC Region IV  
M. B. Fields, NRC Project Manager, Units 2 and 3  
J. A. Sloan, Senior NRC Resident Inspector, San Onofre Units 2 & 3

9512210005 951214  
PDR ADDCK 05000361  
R PDR

JE241