



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379

January 3, 1996

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of )  
Tennessee Valley Authority )

Docket Nos. 50-327  
50-328

SEQUOYAH NUCLEAR PLANT (SQN) - REVISION TO THE TECHNICAL  
SPECIFICATION (TS) BASES (REVISIONS BR-7 AND BR-8, UNIT 1 AND BR-9, UNIT 2)

The purpose of this letter is to inform NRC of changes that TVA has incorporated into the Bases section of the Units 1 and 2 TSs. Specifically, Unit 1 Bases Section 3/4.7.1.2 has been revised to indicate the current operational functions of the turbine-driven auxiliary feedwater level control valves that were modified during the Unit 1 Cycle 7 refueling outage. These valves have been modified to be nonmodulating and automatically open upon an accident signal. The same Bases section has been revised for both units to remove information relative to operator action. This information was misleading with regard to the Chapter 15 analysis of the Updated Final Safety Analysis Report. The enclosure provides the revised Bases pages affected by these revisions.

Please direct questions concerning this issue to Keith Weller at (615) 843-7527.

Sincerely,

R. H. Shell  
Manager  
SQN Site Licensing

Enclosure  
cc: See page 2

160014

9601170181 960103  
PDR ADOCK 05000327  
P PDR

DO301

U.S. Nuclear Regulatory Commission

Page 2

January 3, 1996

cc (Enclosure):

Mr. D. E. LaBarge, Project Manager  
Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852-2739

NRC Resident Inspector  
Sequoyah Nuclear Plant  
2600 Igou Ferry Road  
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323-2711

ENCLOSURE

TECHNICAL SPECIFICATION (TS) BASES CHANGE  
SEQUOYAH NUCLEAR PLANT (SQN) UNITS 1 AND 2  
DOCKET NOS. 50-327 AND 50-328

LIST OF AFFECTED PAGES

Unit 1

B 3/4 7-2a

Unit 2

B 3/4 7-2a