



Carolina Power & Light Company
P.O. Box 10429
Southport, NC 28461-0429

JAN 16 1996

SERIAL: BSEP 96-0015

U. S. Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO 2
DOCKET NO. 50-324/LICENSE NO. DPR-62
REVISED PLANS FOR CORE SPRAY SYSTEM PIPING INSPECTION

Gentlemen:

On November 9, 1995, Carolina Power & Light Company (CP&L) submitted a letter regarding revised plans for core spray system inspection and repair activities for the Brunswick Steam Electric Plant, Unit 2. The purpose of that letter was to (1) inform the Nuclear Regulatory Commission (NRC) of a revision in the schedule for completing the Unit 2 core spray system sparger repair bracket seal weld application and deletion of plans to perform liquid penetrant examination of the repair bracket welds, and (2) request NRC concurrence with elimination of inspections of in-vessel core spray system piping other than weld heat affected zones (HAZs) and the spargers. Based on subsequent discussions with the NRC Staff, CP&L hereby withdraws its request to eliminate inspections of in-vessel core spray piping other than HAZs.

Please refer any questions regarding this submittal to Mr. George Honma at (910) 457-2741.

Sincerely,

G. D. Hicks
Manager — Regulatory Affairs
Brunswick Nuclear Plant

WRM/wrm

cc: Mr. S. D. Ebnetter, Regional Administrator, Region II
Mr. D. C. Trimble, Jr., NRR Project Manager - Brunswick Units 1 and 2
Mr. C. A. Patterson, NRC Senior Resident Inspector - Brunswick Units 1 and 2
The Honorable H. Wells, Chairman - North Carolina Utilities Commission

9601190333 960116
PDR ADDCK 05000324
P PDR

190069

A001
1/0