



Docket No. 50-346  
License No. NPF-3  
Serial No. 1081  
September 11, 1984

RICHARD P. CROUSE  
Vice President  
Nuclear  
(419) 259-5221

Director of Nuclear Reactor Regulation  
Attention: Mr. John F. Stolz  
Operating Reactor Branch No. 4  
Division of Operating Reactors  
United States Nuclear Regulatory Commission  
Washington, DC 20555

Dear Mr. Stolz:

Under separate cover, we are transmitting three (3) original and forty (40) conformed copies of an application for Amendment to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station Unit No. 1.

This application requests that the Davis-Besse Nuclear Power Station Unit 1 Technical Specifications, Appendix A, be revised to reflect the changes attached. The proposed changes involve Table 3.6-2 and bases.

The attachments identify the changes, Safety Evaluation and Significant Hazard Conditions for the revised amendment request submittal dated September 25, 1981 (Serial No. 738) concerning containment isolation valves in the steam generator drain line. This submittal adds the requirement for closure time for the isolation valves MS 603 and MS 611.

This amendment request involves a change to the License. Enclosed is a check for \$150 as requested by 10 CFR 170.12.

Very truly yours,

Enclosure

ks d/7

cc: DB-1 NRC Resident Inspector  
State of Ohio

8409170312 840911  
PDR ADOCK 05000346  
PDR

*Rec'd w/ check  
# 406390 for 150*

*A001  
1/1*