

OPERATING DATA REPORT

DOCKET NO. 50-266

DATE: 01/23/96

COMPLETED BY: M. B. Koudelka

TELEPHONE: 414 755-6480

OPERATING STATUS

1. UNIT NAME: POINT BEACH NUCLEAR PLANT - UNIT 1 . NOTES .
2. REPORTING PERIOD: December - 1995 .
3. LICENSED THERMAL POWER (MWT): 1518.5 .
4. NAMEPLATE RATING (GROSS MWE): 523.8 .
5. DESIGN ELECTRICAL RATING (NET MWE): 497.0 .
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 509.0 .
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 485.0 .
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
NA
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): NA
10. REASONS FOR RESTRICTIONS, (IF ANY):
NA

| | THIS MONTH | YEAR TO DATE | CUMULATIVE |
|--|------------|--------------|-------------|
| 11. HOURS IN REPORTING PERIOD | 744.0 | 8,760.0 | 220,488.0 |
| 12. NUMBER OF HOURS REACTOR WAS CRITICAL | 744.0 | 7,814.8 | 184,654.4 |
| 13. REACTOR RESERVE SHUTDOWN HOURS | 0.0 | 0.0 | 667.3 |
| 14. HOURS GENERATOR ON LINE | 744.0 | 7,769.0 | 181,481.4 |
| 15. UNIT RESERVE SHUTDOWN HOURS | 0.0 | 0.0 | 846.9 |
| 16. GROSS THERMAL ENERGY GENERATED (MWH) | 1129726.0 | 11671152.0 | 257216149.0 |
| 17. GROSS ELECTRICAL ENERGY GENERATED | 385190.0 | 3967720.0 | 86906370.0 |
| 18. NET ELECTRICAL ENERGY GENERATED (MWH) | 369205.0 | 3792433.5 | 82853084.5 |
| 19. UNIT SERVICE FACTOR | 100.0% | 88.7% | 82.3% |
| 20. UNIT AVAILABILITY FACTOR | 100.0% | 88.7% | 82.7% |
| 21. UNIT CAPACITY FACTOR (USING MDC NET) | 102.3% | 89.3% | 77.1% |
| 22. UNIT CAPACITY FACTOR (USING DER NET) | 99.8% | 87.1% | 75.6% |
| 23. UNIT FORCED OUTAGE RATE | 0.0% | 1.3% | 1.5% |
| 24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH): Refueling, 03/30/96, 24 days | | | |
| 25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NA | | | |

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC LETTER DATED SEPTEMBER 22, 1977

9602130217 960207
PDR ADOCK 05000266
PDR

OPERATING DATA REPORT

DOCKET NO. 50-301

DATE: 01/23/96

COMPLETED BY: M. B. Koudelka

TELEPHONE: 414 755-6480

OPERATING STATUS

1. UNIT NAME: POINT BEACH NUCLEAR PLANT - UNIT 2 . NOTES
2. REPORTING PERIOD: December - 1995 .
3. LICENSED THERMAL POWER (MWT): 1518.5 .
4. NAMEPLATE RATING (GROSS MWE): 523.8 .
5. DESIGN ELECTRICAL RATING (NET MWE): 497.0 .
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 509.0 .
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 485.0 .
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
NA
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): power 90%
10. REASONS FOR RESTRICTIONS, (IF ANY):
Self-imposed restriction because of SG tube plugging, pending further evaluation.

| | THIS MONTH | YEAR TO DATE | CUMULATIVE |
|--|------------|--------------|-------------|
| 11. HOURS IN REPORTING PERIOD | 744.0 | 8,760.0 | 205,273.0 |
| 12. NUMBER OF HOURS REACTOR WAS CRITICAL | 722.9 | 7,275.5 | 179,327.1 |
| 13. REACTOR RESERVE SHUTDOWN HOURS | 0.0 | 0.0 | 233.9 |
| 14. HOURS GENERATOR ON LINE | 688.9 | 7,159.7 | 176,854.4 |
| 15. UNIT RESERVE SHUTDOWN HOURS | 0.0 | 0.0 | 302.2 |
| 16. GROSS THERMAL ENERGY GENERATED (MWH) | 887934.0 | 10550228.0 | 254532153.0 |
| 17. GROSS ELECTRICAL ENERGY GENERATED | 298870.0 | 3552150.0 | 86503260.0 |
| 18. NET ELECTRICAL ENERGY GENERATED (MWH) | 283626.0 | 3384134.5 | 82464649.5 |
| 19. UNIT SERVICE FACTOR | 92.6% | 81.7% | 86.2% |
| 20. UNIT AVAILABILITY FACTOR | 92.6% | 81.7% | 86.3% |
| 21. UNIT CAPACITY FACTOR (USING MDC NET) | 78.6% | 79.7% | 82.3% |
| 22. UNIT CAPACITY FACTOR (USING DER NET) | 76.7% | 77.7% | 80.8% |
| 23. UNIT FORCED OUTAGE RATE | 0.0% | 0.2% | 0.9% |
| 24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH): NONE | | | |
| 25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NA | | | |

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC LETTER DATED SEPTEMBER 22, 1977