



Georgia Power

the southern electric system

D. O. Foster
Vice President and Project
General Manager
Vogtle Project

AUG 6 AIO: 30
August 1, 1984

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

File: X7BG03-M59
Log: GN-398

Reference: Vogtle Electric Generating Plant-Units 1 and 2; 50-424, 50-425;
Transamerica Delaval Diesel Generator Thrust Bearings, GN-369
Dated June 4, 1984.

Attention: Mr. James P. O'Reilly

Gentlemen:

In the letter referenced above, Georgia Power Company indicated that the NRC could expect to receive the final corrective action report for this concern on August 17, 1984. This date was predicated on the receipt of the recommended corrective action from Transamerica Delaval in mid-June, 1984. Georgia Power Company was advised that Transamerica Delaval has reforecast their recommended corrective action report for the end of July, 1984.

Transamerica Delaval had submitted a generic recommended corrective action to Georgia Power in April, 1984. Georgia Power Company and its architect-engineer, Bechtel Power Corporation, requested some modifications to the corrective action to address concerns specific to Vogtle equipment. Transamerica Delaval has been unable to complete the re-evaluation of the recommended corrective action as originally forecast; therefore, Georgia Power Company wishes to extend the submittal date for the final corrective action report to November 16, 1984.

This response contains no proprietary information and may be placed in the NRC Public Document Room upon receipt.

Yours truly,

D. O. Foster
D. O. Foster

REF/DOF/tdm

xc: U. S. Nuclear Regulatory Commission, Document Control Desk

R. J. Kelly	D. E. Dutton	J. A. Bailey	L. T. Gucwa
R. E. Conway	W. F. Sanders	O. Batum	M. Malcom
G. F. Head	R. H. Pinson	H. H. Gregory	G. Bockhold
J. T. Beckham	B. M. Guthrie	C. W. Hayes	P. D. Rice
D. N. MacLemore	R. A. Thomas	E. D. Groover	J. L. Vota
W. T. Nickerson	C. S. McCall		

8409240421 B40801
PDR ADOCK 05000424
S PDR

1022 110