

ILLINOIS POWER COMPANY



0981-L
U-10187

CLINTON POWER STATION, P.O. BOX 678, CLINTON, ILLINOIS 61727

August 13, 1984

Docket No. 50-461

Mr. James G. Keppler
Regional Administrator
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Subject: Revised Response to Notice of Violation,
NRC IE Inspection Report Number 50-461/81-25

Dear Mr. Keppler:

This letter is in reference to the Illinois Power Company response U-0396, dated January 8, 1982, to your Notice of Violation dated December 9, 1981, NRC IE Inspection Report Number 50-461/81-25.

The violation identified by the NRC inspector was that "physical and environmental protection from nearby construction activity was not provided for....numerous pre-cut, coiled, temporarily stored Class 1E electrical cables." The response contained in Illinois Power Company letter U-0396 stated in part:

With regard to cable protection, four (4) enclosed staging areas are being constructed in the plant to provide a suitable controlled environment for cables temporarily stored near the construction activity.

Illinois Power Company provides the following revised response:

1. Baldwin Associates procedure BAP 3.3.2, Cable Installation, will incorporate the requirement that cable be stored in designated areas for protection from potential damage. Cable storage prior to installation shall be in accordance with procedure BAP 2.4, Storage and Maintenance.

8409260408 840824
PDR ADOCK 05000461
G PDR

AUG 16 1984

Mr. James G. Keppler


-2-

August 13, 1984

2. Baldwin Associates Quality Control shall perform in-plant storage inspections on a periodic basis to assure storage requirements are maintained.

I trust that our response is satisfactory to maintain compliance with regulatory requirements.

Sincerely yours,

A handwritten signature in dark ink, appearing to read "D. P. Hall". The signature is fluid and cursive, with the first letters of the first and last names being capitalized and prominent.

D. P. Hall
Vice President

JRS/cbs (NRC2)

cc: Director, Office of I&E, US NRC, Washington, DC 20555
NRC Resident Office
Illinois Department of Nuclear Safety