

Wayne H. Jens
Vice President
Nuclear Operations

**Detroit
Edison**

Fermi-2
8400 North Dixie Highway
Newport, Michigan 48166
(313) 586-4150

September 14, 1984
EF2-69708

DMB

Mr. James G. Keppler
Regional Administrator
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

Reference: (1) Fermi 2
NRC Docket No. 50-341
(2) Letter, W. H. Jens to J. G. Keppler,
May 16, 1984, EF2-68536
(3) Letter, W. H. Jens to J. G. Keppler,
June 4, 1984, EF2-68549
(4) Letter, W. H. Jens to J. G. Keppler,
August 15, 1984, EF2-69670


Subject: Amended Report of 10CFR50.55(e) Item 126
"Underrated Terminal Blocks in Limitorque
Valve Operators"

This letter amends Detroit Edison's final report of Item 126, "Underrated Terminal Blocks in Limitorque Valve Operators." This item was originally reported as a potential deficiency on May 4, 1984, and was documented in References (3) and (4).

Subsequently, Detroit Edison decided to replace the deficient Beau Products - 76000 series terminal blocks with Marathon Series 300 terminal blocks instead of the proposed corrective action in Reference (4) to use Kulka 622-5 terminal blocks.

If you have questions concerning this matter, please contact Mr. Lewis P. Bregni at (313) 586-5083.

Sincerely,



cc: P. M. Byron
R. C. DeYoung
R. C. Knop

8409280472 840914
PDR ADDCK 05000341
S PDR

SEP 18 1984
1/0 IE27