

DOCKETED
USNRC

UNITED STATES OF AMERICA '84 OCT -1 A9:33
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD SERVICE
BRANCH

In the Matter of)	
)	Docket Nos. 50-445 and
TEXAS UTILITIES ELECTRIC)	50-446
COMPANY, ET AL.)	
)	(Application for
(Comanche Peak Steam Electric)	Operating Licenses)
Station, Units 1 and 2))	

AFFIDAVIT OF JOHN C. FINNERAN, JR. IN SUPPORT
OF APPLICANTS' REPLY TO CASE'S ANSWER TO
APPLICANTS' MOTION FOR SUMMARY DISPOSITION
REGARDING LOCAL DISPLACEMENTS AND STRESSES

I, John C. Finneran, Jr., being first duly sworn hereby depose and state, as follows: I am the Project Pipe Support Engineer for the Comanche Peak Steam Electric Station. In this position I oversee the design work of all pipe support design organizations for Comanche Peak. A statement of my educational and professional qualifications was received into evidence as Applicants' Exhibit 142B.

Q. What is the purpose of this affidavit?

A. This affidavit provides information in support of Applicants' Reply to CASE's Answer to Applicants' Motion for Summary Disposition Regarding Consideration of Local Displacements and Stresses. I address below the arguments CASE presents in the affidavit of Mr. Doyle ("Affidavit"). CASE takes issue only with respect to Applicants first statement of material fact.

Q. What is your response to CASE's first argument regarding Applicants' motion?

A. CASE disputes Applicants' statement in Attachment A to my original affidavit regarding the effect of neglecting air film insulation in the calculation of the temperature of the tube steel (Affidavit at 3-4). It appears CASE misunderstands Applicants' statement and the principles of air film insulation. CASE seems to believe that the "air film" which Applicants mentioned is located at the interface, or point of contact, between the tube steel and the pipe. There is no air film at the point of contact of the pipe and box frame. This phenomenon occurs over the remainder of the surface area of the box frame. Its insulating effect serves to reduce the rate of heat transfer from the frame to the surrounding atmosphere, thereby causing the frame to expand further and reduce the stress between the pipe and frame. Thus, neglecting this effect as Applicants have done is conservative.

Further, for the situation CASE apparently envisions to exist regarding air film, a gap between the frame and the pipe would have to be present. However, were such a gap to exist, which it does not, the pipe would be able to expand through that gap before contacting the frame thereby reducing the ultimate stress between the pipe and the frame. CASE apparently does not recognize this consideration.

Finally, I note that we have recently performed, at the request of the NRC Staff, a finite difference analysis of the temperature distribution within the box frame of this support. This analysis was provided to CASE with Applicants' letter to the NRC Staff, dated September 24, 1984. A copy of the results of that analysis is attached hereto as Attachment A. As demonstrated therein, Applicants' initial assumption for the temperature distribution in the box frame was very conservative. Applicants originally assumed an average temperature within the frame of 203°F. The finite difference analysis found that the minimum temperature within the frame is actually 206°F. The average temperature in the frame is greater than 220°F. At this higher temperature the frame will expand more than originally assumed and, thus, the stresses in the pipe and the frame will decrease. Accordingly, Applicants' original simplifying assumption was conservative, as we indicated at that time.

Q. What is your reply to CASE's second point?

A. CASE contends that the temperature gradient in the tube steel will vary along the tube from that existing through the tube at the point of contact of the frame and the pipe (Affidavit at 4). However, CASE does not point to any particular effect it believes this varying temperature gradient will have on Applicants' analysis. Consequently, it is not possible to respond directly to CASE's argument. It should be noted, nonetheless, that Applicants' finite

difference analysis mentioned above demonstrated that the temperature gradients along the tube are, in fact (as originally assumed) nearly linear across the frame and along the length of the tube away from the point of contact between the frame and the pipe (Attachment A; sh. 11 of 11). Thus, although the gradients do vary, Applicants' assumption of linearity for taking an average temperature of the tube was reasonable and, in fact, conservative given the conclusion from the finite element analysis that the lowest temperature in the frame (206°F) is actually higher than the average temperature (203°F) originally assumed. Thus, the expansion of the frame will actually be greater than initially estimated.

Q. What is your response to CASE's third assertion?

A. CASE asserts that the expansion of the frame calculated by Applicants will actually be "far less" because of the thermal gradients (Affidavit at 4). As I have already noted, Applicants' original assessment was appropriate and very conservative, actually underestimating the expansion of the frame. CASE's assertion to the contrary is simply wrong.

CASE also claims that the thermal gradients within the box frame will give rise to differential expansion of the frame, creating internal thermal stresses (Affidavit at 4-5). The Board has already ruled that such internal thermal

stresses need not be considered under the ASME Code (Memorandum and Order (Thermal Stress in Pipe Supports), July 6, 1983).

Q. What is your response to CASE's fourth argument?

A. CASE again asserts that the thermal gradients within the box frame are not linear (relying on CASE Exhibits 669B, Items 13E-13J) and, thus, stresses will be higher due to "direct bending . . . only as a result of thermal constraint" (Affidavit at 5). In the first instance, it is not possible to draw any meaningful conclusion by comparing CASE's exhibits with the support at issue here. Heat flow calculations involve many parameters and are highly dependent on configuration, proximity to the pipe, number of and extent of contact points with the pipe, etc. None of the configurations in CASE's exhibits are similar to the support involved here. Finally, to the extent CASE again argues that stresses resulting from "thermal constraint" need be considered, as I already noted the Board previously ruled that such stresses need not be considered.

Q. What is your reply to CASE's final argument?

A. CASE's final assertion is that Applicants' employed an incorrect value for Young's Modulus in calculating the expansion of the frame (Affidavit at 5). CASE apparently assumed Applicants employed an AISC formula for calculating the coefficient of thermal expansion. However, because this support is an ASME support, Applicants utilized the value

for the coefficient of thermal expansion set forth in Appendix I to Section III of the ASME Code. Applicants used the value set forth in Table I-50 (Attachment B) for the coefficient at 200°F (6.38×10^{-6}) adjusted for the 203°F temperature assumed for the frame (6.387×10^{-6}). Finally, it should be noted that although CASE apparently contends Applicants should have used the coefficient CASE derived, CASE does not acknowledge that to do so would be less conservative in that the expansion of the frame would be greater and, thus, lower stresses would be created in the frame and the pipe.

- Q. Do you have any further comments regarding CASE's assertions?
- A. To summarize my previous comments, I note that none of CASE's arguments raised valid concerns. CASE has failed to point to any significant effect that should have been, but was not, considered in Applicants' analysis.

John C. Finneran Jr.
John C. Finneran, Jr.

STATE OF TEXAS
COUNTY OF SCHERVILLE

Subscribed and sworn to before me this 28th day of September, 1984.

Bruce J. Hodges
Notary Public

MY COMMISSION EXPIRES MARCH 28, 1988

BY J. SHIN DATE 9/19/84

SHEET 1 OF 1

CHKD. BY Pat DATE 9/19/84

OFS NO 2970.002 DEPT NO 462

CLIENT TUGC

PROJECT COMANCHE PEAK S.E.S

SUBJECT 3-D OPEN END BOX BEAM

Assumptions

- 1) Pipe surface temperature 350°F
- 2) Hollow box beams are located vertically.
- 3) Passing connecting air inside hollow box beam is 104°F .

To find Temperature distribution, a model for computer code HEATING 5 is utilized.

Proper natural heat convection inside gap between pipe and box beam, and inside hollow box beam is included. Radiation between pipe and box beams, and conduction thru direct contact are calculated with the proper input data by HEATING 5 in 3-D model. Also natural convection at the surface of box beams are accounted in the model.

The results are shown in the next page of calculation.

EBASCO SERVICES INCORPORATED

BY J. SHIN DATE 9/18/84

SHEET 1 OF 11

CHKD. BY REDA DATE 9/19/84

OPS NO. 2970.102 DEPT. NO. 462

CLIENT TUGC

PROJECT COMANCHE PEAK S.E.S.

SUBJECT 3-D OPEN END BOX BEAM

Reference)

1) FLOW OF FLUIDS THROUGH VALVES, FITTINGS
AND PIPE BY CRANE

2) Heat Transfer by A. J. Chapman
Macmillan Co.

BY J SHIN DATE 9/18/84

SHEET 2 OF 11


CHKD. BY R. [signature] DATE 9/18/84

OFS NO 2970 002 DEPT. NO 462

CLIENT TUGC

PROJECT COMANCHE PEAK SES

SUBJECT 3-D OPEN END BOX BEAMS



Purpose: To find out temperature distribution of the box beam

Major assumptions

- 1) Pipe surface temperature 350°F ✓
- 2) Hollow box beams are located vertically as shown in the Figure. ✓
- 3) No significant pressure is applied between pipe and box beam (or line contact)

side of pipe
extends more
contact with
box beam and heat will transfer more readily

- 4) Symmetry with respect to $x = 1/2$

BY J. SHIN DATE 9/18/84

SHEET 3 OF 11

CHKD. BY Notch DATE 9/19/84

OFS NO. 2970.012 DEPT. NO. 462

CLIENT TUGC

PROJECT COMANCHE PEAK SES

SUBJECT 3-D OPEN END SIX BEAMS

5) Passing convecting air inside hollow box beam is 104°F , this is conservative since air will be hotter

6) Air temperature of the gap between pipe and box beam is 104°F for conservatism ok

To find temperature distribution a model for computer code HEATING 5 is considered as depicted in the next page. (one quadrant considered)


Since height of roughness of commercial stainless steel is 0.00015 inches, $2 + 0.00015 = 2.00015$ is assumed as direct contact area. (Ref. 1)

Now to find radiation shape factor.

for gray body emissivity $\epsilon_1 = 0.95$ and $\epsilon_2 = 0.95$
(Ref. 2 Pg. 426)

$$q_{12} = \frac{A_1 F_{1-2} \sigma (T_1^4 - T_2^4)}{\frac{1}{\epsilon_1} + \frac{1}{\epsilon_2} - 1}$$


$$0.1549657 \times 10^{-8} \quad \sigma: 0.1713 \times 10^{-8}$$



SEE TD PGE 5

OFFS NO. 2976 012 DEPT NO. 462

CLIENT TUGC
PROJECT COMANCHE PEAK S.E.S.
SUBJECT 3-D OPEN END BOX BEAMS



EBASCO SERVICES INCORPORATED

BY J. SHIN DATE 9/18/84

SHEET 5 OF 11

CHKD. BY RCH DATE 9/19/84

OFS NO. 2370.002 DEPT. NO. 462

CLIENT TUGC

PROJECT CEMANICHE PEAK S.G.S

SUBJECT 3-D OPEN END BOX BEAMS

Where regions 13, 15, 23, 24, 25, 26 and 27 signify the pipe surface for this model and regions 28, 29, 30, 31, 32, 33, 34 and 35 are for gap.

FROM PAGE 3

Two parallel plates in the subdivided region
for gaps 35 and 28 (Ref 2 page 320)

$$R_1 = \frac{L}{D} = \frac{2.5}{0.5} = 5 \quad R_2 = \frac{W}{D} = \frac{2.5}{0.5} = 5$$

$$F_{12} = 0.75 \rightarrow 1.1624 \times 10^{-9}$$

2" long 1" gap for gaps 34 and 29

$$R_1 = \frac{2}{1} = 2 \quad R_2 = \frac{2}{1} = 2$$

$$F_{12} = 0.53 \rightarrow 8.242 \times 10^{-10}$$

2" long 3" gap for gaps 33 and 30

$$R_1 = 1.667 \quad R_2 = 0.667$$

$$F_{12} = 0.2 \rightarrow 3.6997 \times 10^{-10}$$

0.5" long 6.5" gap

$$F_{12} = 0.0075 \rightarrow 1.7624 \times 10^{-11}$$

The foregoing radiation is between the pipe and box beams.

EBASCO SERVICES INCORPORATED

BY J. SHIN DATE 9/19/04

SHEET 6 OF 11

CHKD BY ~~JS~~ DATE 9/19/04

OFS NO. 2970.002 DEPT. NO. 462

CLIENT TUGG

PROJECT CEMANCHE PEAK S.E.S.

SUBJECT 3-D OPEN END BOX BEAMS

To calculate natural convection in the gap between the pipe and the box beam.

Chapman (Ref 2) pp 277, 275 and 418

Heat transfer coefficient for air
for B.C ③ horizontal plates

$$h = 0.12 \left(\frac{\Delta t}{L} \right)^{1/4} = \frac{0.12}{\left(\frac{5}{12} \right)^{1/4}} (\Delta t)^{1/4} = 0.15 (\Delta t)^{1/4}$$

for B.C ③ vertical plates

$$h = 0.29 \left(\frac{\Delta t}{L} \right)^{1/4} = \frac{0.29}{\left(\frac{5}{12} \right)^{1/4}} (\Delta t)^{1/4} = 0.32 (\Delta t)^{1/4}$$

Heat transfer coeff. for B.C ①, ② and ④

Grashoff number should be calculated.

$$N_{Gr} = (g \Delta t) \left(\frac{L^3}{\nu^2} \right)$$

$$T_{air} \text{ set } \left(\frac{260 + 340}{2} + 104 \right) / 2 = 202 \rightarrow 200^\circ F$$

$$N_{Pr} = 0.694, \quad \nu = 0.8636 \text{ ft}^2/\text{hr}$$

$$L = \frac{26}{12} = 2.17 \text{ (ft)}$$

$$\Delta t = \frac{260 + 340}{2} - 104 = 196 (^\circ F)$$

BY J. SHIN DATE 9/18/84

SHEET 7 OF 11

CHKD. BY _____ DATE _____

OFS NO. 2970.002 DEPT. NO. 462

CLIENT TUGC

PROJECT COMANCHE PEAK S.E.S

SUBJECT 3-D OPEN END BOX BEAMS

$$\beta = \frac{1}{T} = \frac{1}{460 + 200} = \frac{1}{660} \text{ expansion coeff for air}$$

$$N_{Gr} Pr = \frac{-196}{660} \left(\frac{26}{12} \right)^3 \frac{32.2 \times 3600^2}{0.8636^2} \times 0.694$$

$$= 1.17 \times 10^9 > 10^9$$

turbulent flow!

$$h = 0.19 (Gr)^{1/4} \text{ for vertical plates}$$

$$h = 0.22 (Gr)^{1/3} \text{ for horizontal plates}$$

This is ok for heat transfer from plate up, but overestimates heat transfer from plate down, which is ok since it will lead to cooler frame under surface


EBASCO SERVICES INCORPORATED

BY W. A. [unclear] DATE 9/12/84
 CHKD BY [unclear] DATE 9/19/84
 CLIENT TUST
 PROJECT Concrete Park
 SUBJECT Heat Transfer from Pipe to Box

SHEET 8 OF 11
 OPS NO. 8970.002 DEPT. NO. 462

Assuming conduction through an air space, an effective interface heat transfer coefficient may be assumed, assuming that the heat transfer through the air space is a function of radiation. This is a 3-D problem.

	δ in	ft	$h_i = \frac{k}{\delta} = \frac{0.22}{\delta}$ $h_i \delta = 0.22$	$L = \sqrt{16\delta - \delta^2}$ in
direct contact	0	0	∞	0
	0.0105	0.000875	1760	
	0.02	0.001667	880	0.069
	0.03	0.0025	640	0.126
	0.04	0.003333	480	0.179
gap conduction	0.05	0.004167	360	
	0.06	0.005	267	0.506
	0.07	0.005926	199	0.715
	0.08	0.007143	145	1.00
	0.09	0.008333	107	1.43
	0.10	0.010000	80	



$$(8 - \delta)^2 + L^2 = 8^2$$

$$L^2 = 8^2 - (8 - \delta)^2$$

$$L = \sqrt{64 - (8 - \delta)^2}$$

$$L = \sqrt{16\delta - \delta^2}$$

Height of roughness of commercial stainless steel
 0.00015 inches. Assuming direct contact as
 2x or 0.0003 inches.

EBASCC SERVICES INCORPORATED

BY M. ZUBOYSC DATE 9/14/86

SHEET 9 OF 11

CHKD BY REB DATE 9/19/86

OPS NO 2970 002 DEPT. NO 462

CLIENT TUGG

PROJECT C. MANCHE PEAK SES

SUBJECT 3-D OPEN END BOX BEAMS

Update 1

Add 2 regions in contact and change

the BC for regions ① and ⑩ to include

heat conduction through air. $h_{eq} = 53$

corresponding to equivalent gap of .008"
length of contact .0003"

Regions 21 and 22 will have BC 1

(i.e. contact temp of 350°)


Region 1 and 10 will have new BC

10, with $h = 53$ and radiation of shape

factor 1.0 i.e. $15.5 E-10$

375

1419




00 25E-5

042

1.082975

1.083

63 708



EBASCO SERVICES INCORPORATED

BY J SHIN DATE 9/18/84SHEET 10 OF 11CHKD BY POW DATE 9/19/84OFS NO. 2970.062 DEPT. NO. 462CLIENT TUGCPROJECT COMANCHE PEAK S.E.SSUBJECT 3-D OPEN END BOX BEAMS

HEATING5 computer code was run with
the program model and input data.

The results are shown in the next pages.

COPYBE, STAFF, HTR.

REWIND, HTR.

COPY, HTR, PHEATS.

REWIND, HTR, PHEATS.

BEGIN, HEATS, HTR, 0.0, 0.0, 0.0, 0.0.

ATTACH, MEPROC, ID=SCG, PW=ITEL.

MEPROC, OUTPUT.

MEADDRS. M ZUZOVSKY EBASCO SERVICES INC TW WORLD TRADE CENTER

MEADDRS. 99TH FLOOR NEW YORK, N.Y. 10048

MEINFOR. SEND BY FIRST CLASS MAIL-WAKE TWO COPIES

MEPRINT. TUSG - TEMPERATURE IN BOY BEAM AROUND PIPE 2

EXIT(U)

TUSG - TEMPERATURE IN TUBE STEEL FRAME 2

3000	6	35	2	1	0	4	13
11	11	4					
1	750	5.7-6					
1	1	.667	.708	1.042	1.082975	0.0	.417
1		10				8	8
2	1	.667	.708	.843	1.042	0.0	.417
1		13				8	8
3	1	.667	.708	.667	.833	0.0	.417
1		13				8	8
4	1	.667	.708	.500	.667	0.0	.417
1		13				8	8
5	1	.667	.708	.417	.500	0.0	.417
1		13				8	8
6	1	.553	.667	.375	.417	0.0	.417
1						8	8
7	1	.417	.583	.375	.417	0.0	.417
1						8	8
8	1	.250	.417	.375	.417	0.0	.417
1						8	8
9	1	.042	.250	.375	.417	0.0	.417
1						8	8
10	1	2.55-5	0.042	.375	.417	0.0	.417
1						8	8
11	1	0.0	.708	0.0	.042	0.0	.417
1						8	8
12	1	1.042	1.083	0.0	1.083	0.0	.417
1						8	8
13	1	.042	.250	.417	.500	0.0	.417
1						8	8
14	1	.667	.708	.042	.417	0.0	.417
2						8	8
15	1	.250	.417	.042	.5	0.0	.417
1						8	8
16	2	0.0	.667	.042	.375	.042	.375
2							
17	1	.708	1.042	0.0	1.083	0.0	.042
2						8	8
18	1	.708	1.042	0.0	1.083	.375	.417
2						8	8
19	1	0.0	.667	.042	.375	0.0	.042
2						8	8
20	1	0.0	.667	.042	.375	.375	.417
2						8	8
21	1	.667	.708	1.082975	1.083	0.0	.417
1		1				8	8
22	1	0.0	2.55-5	.375	.417	0.0	.417
1						8	8
23	1	.417	.583	.417	.500	0.0	.417
1						8	8

26	1	.553	.66	.667	.673	.0	.417
27	1	.553	.66	.673	1.042	.0	.417
28	1	.042	.25	.417	.420	.0	.417
29		.250	.417	.417	.420	.0	.417
30		.417	.583	.417	.420	.0	.417
31		.583	.66	.417	.420	.0	.417
32		.660	.667	.420	.500	.0	.417
33		.660	.667	.500	.667	.0	.417
34		.660	.667	.667	.833	.0	.417
35		.660	.667	.873	1.042	.0	.417

2	AIR	.0170
1	CSTEEL	25.70
1	350.	
2	250.	
3	200.	
4	150.	
1	2	350.

2	3							
11.65	-10							
8.215	-10							
3.1005	-10							
.1165	-10							
1	104.0							
	.220	.333						
7	104.0							
	.190	.333						
1	104.0							
	.190	.333						
1	104.0							
	.150	.25						
10	350.0							
53. 15.55	-10							
11	3							
12	2	.239	.25					
		104.						
13	1	174.						
		.320	.25					
0.0	2.55-5	.042	.250	.417	.583	.660	.667	
.700	1.042	1.042						
1	1	2	2	2	1	1	1	
0.0	.042	.375	.417	.417	.500	.667	.833	
1.042	1.042-75	1.042						
1	2	1	1	1	2	2	2	
1	1							
0.0	.042	.375	.417					
1	1	1						

BY J. SHIN DATE 9/18/84

SHEET 11 OF 11

CHKD BY DATE

OFF NO 2976 012 DEPT NO 462

CLIENT TUSC

PROJECT COMANCHE PEAK S.E.S.

SUBJECT 3-D OPEN END BOX BEAMS




TABLE I-5.0
COEFFICIENTS OF THERMAL EXPANSION

Materials	Coeff- ficient ¹	Temperature (F)															
		70	100	150	200	250	300	350	400	450	500	550	600	650	700	750	800
Carbon steel; Carbon-moly steel; low-chrome steels (through 3 Cr)	A	6.07	6.20	6.44	6.67	6.89	7.10	7.33	7.54	7.76	7.96	8.16	8.35	8.54	8.76	8.94	9.16
	B	6.07	6.13	6.25	6.38	6.49	6.60	6.71	6.82	6.92	7.02	7.12	7.23	7.33	7.44	7.54	7.65
	C	0	.0023	.0061	.0099	.0140	.0182	.0226	.0270	.0316	.0362	.0411	.0460	.0511	.0563	.0616	.0670
Intermediate-chrome steels (5 Cr through 9 Cr)	A	5.73	5.90	6.13	6.30	6.42	6.54	6.71	6.85	7.03	7.16	7.35	7.47	7.60	7.75	7.90	8.02
	B	5.73	5.79	5.92	6.04	6.12	6.19	6.27	6.34	6.42	6.50	6.58	6.66	6.73	6.80	6.88	6.96
	C	0	.0022	.0058	.0094	.0133	.0171	.0210	.0250	.0293	.0335	.0380	.0424	.0469	.0514	.0562	.0610
High-chrome steels (12 Cr through 17 Cr)	A	5.24	5.34	5.53	5.72	5.87	6.05	6.21	6.36	6.50	6.66	6.80	6.94	7.01	7.08	7.21	7.36
	B	5.24	5.29	5.40	5.50	5.58	5.66	5.74	5.81	5.89	5.96	6.05	6.13	6.20	6.26	6.33	6.39
	C	0	.0020	.0053	.0086	.0121	.0156	.0193	.0230	.0269	.0308	.0349	.0390	.0431	.0473	.0516	.0560
Austenitic stainless steel (18 Cr 8 Ni)	A	9.11	9.21	9.39	9.50	9.66	9.73	9.87	9.96	10.09	10.20	10.34	10.43	10.54	10.66	10.81	10.90
	B	9.11	9.16	9.25	9.34	9.41	9.47	9.53	9.59	9.65	9.70	9.76	9.82	9.87	9.93	9.99	10.05
	C	0	.0034	.0090	.0146	.0203	.0261	.0320	.0380	.0441	.0501	.0562	.0624	.0687	.0751	.0815	.0880
25 Cr-20 Ni	A	7.48	7.60	7.78	7.96	8.13	8.27	8.45	8.57	8.74	8.88	9.02	9.16	9.30	9.42	9.56	9.70
	B	7.48	7.54	7.65	7.76	7.84	7.92	8.00	8.08	8.15	8.22	8.30	8.38	8.45	8.52	8.60	8.68
	C	0	.0028	.0074	.0121	.0170	.0218	.0269	.0320	.0372	.0424	.0479	.0533	.0588	.0644	.0702	.0760
Nickel-Chrome-Iron	A	7.13	7.26	7.46	7.63	7.77	7.91	8.02	8.10	8.16	8.23	8.33	8.43	8.53	8.63	8.73	8.98
	B	7.13	7.20	7.30	7.40	7.48	7.56	7.63	7.70	7.75	7.80	7.85	7.90	7.95	8.00	8.05	8.10
	C	0	.0026	.0070	.0115	.0161	.0209	.0256	.0305	.0353	.0402	.0452	.0502	.0553	.0605	.0657	.0710
Aluminum	A	12.25	12.62	13.12	13.52	13.80	14.06	14.34	14.67	14.95	15.24	15.49	15.79
	B	12.25	12.39	12.67	12.90	13.12	13.28	13.44	13.60	13.75	13.90	14.05	14.20
	C	0	.0046	.0123	.0200	.0283	.0366	.0453	.0539	.0628	.0717	.0810	.0903

NOTE:

1. Coefficient A is the instantaneous coefficient of thermal expansion $\times 10^6$ (in./in./F). Coefficient B is the mean coefficient of thermal expansion $\times 10^6$ (in./in./F) in going from 70 F. to indicated temperature. Coefficient C is the linear thermal expansion (in./ft.) in going from 70 F. to indicated temperature.

DOCKETED
USNRC

'84 OCT -1 A9:33

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
BEFORE THE ATOMIC SAFETY AND LICENSING BOARD
SECRETARY
& SERVICE
BRANCH

In the Matter of)
)
TEXAS UTILITIES ELECTRIC) Docket Nos. 50-445 and
COMPANY, et al.) 50-446
)
(Comanche Peak Steam Electric) (Application for
Station, Units 1 and 2)) Operating Licenses)

CERTIFICATE OF SERVICE

I hereby certify that copies of "Applicants' Reply to CASE's Answer to Applicants' Motion for Summary Disposition Regarding Local Displacement and Stresses," in the above-captioned matter was served upon the following persons by express delivery (*), or deposit in the United States mail, first class, postage prepaid, this 28th day of September, 1984, or by hand delivery (**) on the 1st day of October, 1984.

**Peter B. Bloch, Esq.
Chairman, Atomic Safety and
Licensing Board
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Chairman, Atomic Safety and
Licensing Appeal Panel
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

*Dr. Walter H. Jordan
881 West Outer Drive
Oak Ridge, Tennessee 37830

Mr. William L. Clements
Docketing & Service Branch
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

*Dr. Kenneth A. McCollom
Dean, Division of Engineering
Architecture and Technology
Oklahoma State University
Stillwater, Oklahoma 74074

**Stuart A. Treby, Esq.
Office of the Executive
Legal Director
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Mr. John Collins
Regional Administrator,
Region IV
U.S. Nuclear Regulatory
Commission
611 Ryan Plaza Drive
Suite 1000
Arlington, Texas 76011


Chairman, Atomic Safety and
Licensing Board Panel
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Renea Hicks, Esq.
Assistant Attorney General
Environmental Protection
Division
P.O. Box 12548
Capitol Station
Austin, Texas 78711

Lanny A. Sinkin
114 W. 7th Street
Suite 220
Austin, Texas 78701

*Mrs. Juanita Ellis
President, CASE
1426 South Polk Street
Dallas, Texas 75224

Ellen Ginsberg, Esquire
Atomic Safety and Licensing
Board Panel
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555



William A. Horin

cc: John W. Beck
Robert Wooldridge, Esq.