

TABLE 3.3.5.2-1

REMOTE SHUTDOWN MONITORING INSTRUMENTATION

| <u>FUNCTIONAL UNIT AND INSTRUMENT NUMBER</u> | <u>READOUT LOCATION</u> | <u>MINIMUM CHANNELS OPERABLE</u> |
|--|-------------------------|----------------------------------|
| 1. Reactor Vessel Pressure (C32-PI-3332 and C32-PT-3332) | RSP* | 1 |
| 2. Reactor Vessel Water Level (B21-LT-NO17D-3, B21-LSH-NO17D-3) (B21-LI-3331, B21-LI-R604AX, B21-LT-3331, B21-LT-NO26A) | RSP* | 1 |
| 3. Suppression Chamber Water Level (CAC-LI-3342 and CAC-LT-3342) | RSP* | 1 |
| 4. Suppression Chamber Water Temperature (CAC-TR-778-7) | RSP* | 1 |
| 5. Drywell Pressure (CAC-PI-3341 and CAC-PT-3341) | RSP* | 1 |
| 6. Drywell Temperature (CAC-TR-778-1,3,4) | RSP* | 1 |
| 7. Residual Heat Removal Head Spray Flow (E11-FT-3339 and E11-FI-3339) | RSP* | 1 |
| 8. Residual Heat Removal System Flow (E11-FT-3338, E11-FI-3338, and E11-FY-3338) | RSP* | 1 |
| 9. Residual Heat Removal Service Water Discharge Differential Pressure (E11-PDT-NOO2BX and E11-PDI-3344) | RSP* | 1 |

*Remote Shutdown Panel, Reactor Building 20' Elevation

8410030178 E40926
PDR ADOCK 05000324
P PDR

BRUNSWICK - UNIT 2

3/4 3-48

Amendment No.

TABLE 4.3.5.2-1

REMOTE SHUTDOWN MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

| <u>FUNCTIONAL UNIT AND INSTRUMENT NUMBER</u> | <u>CHANNEL CHECK</u> | <u>CHANNEL CALIBRATION</u> |
|--|----------------------|----------------------------|
| 1. Reactor Vessel Pressure (C32-PI-3332 and C32-PT-3332) | M | Q |
| 2. Reactor Vessel Water Level (B21-LT-N017D-3, B21-LSH-N017D-3) (B21-LI-3331, B21-LI-R604AX, B21-LF-3331, B21-LT-N026A) | NA M | Q Q |
| 3. Suppression Chamber Water Level (CAC-LI-3342 and CAC-LT-3342) | M | R |
| 4. Suppression Chamber Water Temperature (CAC-TR-778-7) | M | R |
| 5. Drywell Pressure (CAC-PI-3341 and CAC-PT-3341) | M | Q |
| 6. Drywell Temperature (CAC-TR-778-1,3,4) | M | R |
| 7. Residual Heat Removal Head Spray Flow (E11-FI-3339 and E11-FI-3339) | M | Q |
| 8. Residual Heat Removal System Flow (E11-FI-3338, E11-FI-3338, and E11-FI-3338) | M | Q |
| 9. Residual Heat Removal Service Water Discharge Differential Pressure (E11-PDI-N002BX and E11-PDI-3344) | M | Q |

CONTAINMENT SYSTEMSGAS ANALYZER SYSTEMSLIMITING CONDITION FOR OPERATION

3.6.6.4 Two independent gas analyzer systems for the drywell and suppression chamber shall be OPERABLE with each system consisting of an oxygen analyzer and a hydrogen analyzer.

APPLICABILITY: CONDITION 1.

ACTION:

- a. With one oxygen and/or one hydrogen analyzer inoperable, restore at least two oxygen and two hydrogen analyzers to OPERABLE status within 31 days or be in at least STARTUP within the next 8 hours. The provisions of Specification 3.0.4 are not applicable.
- b. With no gas analyzer OPERABLE for oxygen and/or hydrogen, be in at least STARTUP within 8 hours.

SURVEILLANCE REQUIREMENTS

4.6.6.4 Each gas analyzer system (CAC-AT-4409, Division I and CAC-AT-4410, Division II) shall be demonstrated OPERABLE at least once per 92 days by performing a CHANNEL CALIBRATION using standard gas samples containing a nominal:

- a. Zero volume percent hydrogen, balance nitrogen.
- b. Seven to ten volume percent hydrogen, balance nitrogen.
- c. Twenty-five to thirty volume percent hydrogen, balance nitrogen.
- d. Zero volume percent oxygen, balance nitrogen.
- e. Seven to ten percent oxygen, balance nitrogen.
- f. Twenty to twenty-five percent oxygen, balance nitrogen.