

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION


In the Matter of)
NEW YORK POWER AUTHORITY) Docket No. 50-333
James A. FitzPatrick Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the New York Power Authority, as holder of Facility Operating License No. DPR-59, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.


The proposed Amendment to Appendix A of Facility Operating License No. DPR-59 is required to conduct the hydrogen addition test. The Amendment revises the Main Steam Line Radiation trip level setpoint in Table 3.1-1 (pages 41a and 43a), Table 3.2-1 (pages 64 and 65) and the Bases on pages 33 and 57. These changes would incorporate a higher trip setpoint for the radiation monitors to take into account the increased background radiation levels occurring during the test.

NEW YORK POWER AUTHORITY


J.P. Bayne
First Executive Vice President &
Chief Operations Officer
Nuclear Generation

State of New York
County of Westchester

Subscribed and sworn to before
me this 2 day of October, 1984.


Notary Public

JEANNE LA LUNA
NOTARY PUBLIC, STATE OF NEW YORK
NO. 60-4514305
QUALIFIED IN WESTCHESTER COUNTY
TERM EXPIRES MARCH 30th 1985....

8410050382 841002
PDR ADOCK 05000333
P PDR

ATTACHMENT I

Proposed Technical Specification Changes
Main Steam Line Radiation Monitor Trip Level Setting
Related to Hydrogen Addition Test

New York Power Authority

James A. FitzPatrick Nuclear Power Plant

Docket No. 50-333